February 28, 2013

Mr. Ismael Lopez

Department of Beaches & Harbors

Design Control Board

13483 Fiji Way Trailer #3

Marina del Rey, CA 90292

Attention: Planning

Re: Oxford Retention Basin Multi-Use Enhancement Project

Dear Mr. Lopez:

We are pleased to submit the referenced project for final design approval. The following is a summary of our response to comments received during our last meeting with the Design Control Board (DCB) in September, 2012. The Project Design Concept is also enclosed to provide a thorough Project Scope of Work.

We look forward to presenting this project for your consideration of the final design approval by your Board at the March, 2013 Design Control Board meeting.

Sincerely,

Joshua Svensson, PE

Los Angeles County Department of Public Works

OXFORD RETENTION BASIN

#	Comment	Meeting	Source	Response
1	What do you mean by "stabilized decomposed granite"? Will it be sprayed with oil? Will the stabilizer contaminate the water?	DCB-September 19,2012	DCB's Chair	The DG will be mixed with the stabilizer, which will not have any negative impacts to water quality.
2	I'm very disappointed in the Washington Ave plan area, because it looks as though there were opportunities there to let the path and the fence be disengaged from the sidewalk, and I'd like to see that exploited The experience of walking down the path should be something different than walking on the sidewalk.	DCB-September 19,2012	DCB's Chair	Unfortunately, realignment of the walking path is likely not feasible as we are have already maximized encroachment onto the site.
3	The name of the project sounds too much like "flood control"	DCB-September 19,2012	DCB's Chair	We agree, and are looking into this.
4	Who will be the "architectural curator"? Is there an individual who will make sure the elements are all cohesive?	DCB-September 19,2012	DCB's Chair	This role will be fulfilled by our landscape architect.
5	I hope that the construction budget reflects the prioritization of the work?	DCB-September 19,2012	DCB's Chair	It does. The recreational, habitat, and aesthetic enhancements compose a significant portion of the total budget.
6	I and many members of the community are concerned about odors from basin.	DCB-September 19,2012	Public Member	We believe sewer gas is/was the primary source of odors, we have resolved many of the issues, and we are actively investigating all reports.
7	Will the contaminated water from the Marina cause issues with the habitat in Oxford?	DCB-September 19,2012	Public Member	We don't believe there will be significant negative effects due to water from the Marina, and the project may in fact improve Marina water quality
8	Can you include bathrooms in the project?	DCB-September 19,2012	Public Member	(DBH Answered): there are several public bathrooms in the vicinity; we will plan to include maps to bathrooms in the site signage.
9	Are there records of oil wells in the area?	DCB-September 19,2012	Public Member	Not in the area of this site.
10	Will this require partial closure of Admiralty or Washington?	DCB-September 19,2012	Public Member	Yes, it will likely require partial closure of Admiralty, but the traffic control plans have not been finalized. We will work to minimize this disruption.



Approved Jahrel V. Ochollin

Patrick V. DeChellis

March 14, 2012

Approved Diego Cadena

TO:

Patrick V. DeChellis

Diego Cadena

FROM:

Sree Kumar

Design Division

Gary Hildebrand

Watershed Management Division

PROJECT DESIGN CONCEPT OXFORD RETENTION BASIN MULTIUSE ENHANCEMENT PROJECT PROJECT ID FCC0001176, PCA JX0039

RECOMMENDATIONS

- 1. Approve the Project Design Concept (PDC) for the Oxford Retention Basin Multiuse Enhancement Project (Project) as described herein.
- 2. Approve a Project budget of \$10,190,000 and request Watershed Management Division (WMD) to arrange for necessary financing over Fiscal Years (FY) 2012-15 as described in this PDC.

BACKGROUND

The Project is located at Oxford Retention Basin (Oxford Basin), a flood control facility operated by the Los Angeles County Flood Control District (LACFCD), one block north of Marina Del Rey Harbor Basin E (Basin E) in the unincorporated community of Marina Del Rey (Thomas Guide 671-J6).

The Project will mitigate localized flooding, address water quality deficiencies, enhance native habitat, improve the site's aesthetics, and provide passive recreation features.

WMD completed a Project Concept Report for the Project dated December 31, 2008. Design Division (DES) has studied and evaluated the alternatives for the Project and has refined the project scope and schedule.

PROJECT DESCRIPTION

The Project's scope of work is as follows:

LACFCD FUNDED WORK:

- Excavation of approximately 2,700 cubic yards (CY) of accumulated sediment along the bottom of Oxford Basin to restore basin capacity. The sediment will be disposed at a Class III landfill.
- Construction of a parapet wall along the northwestern and southern boundaries of Oxford Basin. The reinforced concrete wall will be approximately 1,050 linear feet long and a maximum of 2 feet in height. The wall will provide enhanced protection from flooding along Washington Avenue.
- Construction of a berm between the two existing tide gates and reprogramming the opening cycle of the existing tide gates to improve water circulation in Oxford Basin.
- Mitigation of localized flooding by modifying the existing 7-foot-wide catch basin on the south side of Oxford Avenue at the intersection of Oxford Avenue and Olive Street. The catch basin will be modified and a Tideflex "Check-mate" flap-gate will be installed at the connection to Project 5243. Local drainage will be further improved by the removal and replacement of existing Tideflex G-37 valves in four catch basins on Oxford Avenue and Olive Street with more efficient Tideflex "Check-mate" flap-gates.
- Installation of trash BMPs at the outlets of Storm Drain Project Nos. 5243 and 3872 to remove gross solids in urban and storm water runoff.
- Construction of a maintenance vehicle access ramp from Admiralty Way adjacent to the tide gate control house.
- Installation of a steel-grated landing above the two tide gate inlet structures in the basin to provide safer access for trash rack maintenance.
- Construction of a permanent boat ramp near the outlet of Project No. 3872 to allow Flood Maintenance Division (FMD) and the Department of Beaches and Harbors (DBH) access to Oxford Basin for routine maintenance, trash removal, and water quality monitoring.

COUNTY FUNDED WORK:

- Construction of an 8-foot-wide walking trail with wildlife-friendly lighting around the perimeter of Oxford Basin. The sidewalk along Admiralty Way will be replaced with landscaped parkway and integrated with the new walking trail.
- Reconstruct approximately 400 linear feet of slope along Admiralty Way near Project 3872 with geogrid or an approved equal to stabilize the underlying soils.
- Installation of approximately 3,550 linear feet of 4-foot-high ornamental steel fence around the perimeter of Oxford Basin.
- Removal of existing vegetation and approximately 6,200 CY of contaminated soils along the perimeter of Oxford Basin (3,200 CY and 3,000 CY to be disposed at Class I and Class III landfills, respectively) and replacement with clean imported fill and attractive, drought-tolerant native plants to provide aesthetic enhancement, which will also serve to enhance the habitat surrounding Oxford Basin.
- Installation of an irrigation system to establish the new native plants.
- Construction of six observation areas with park benches overlooking Oxford Basin: two along Washington Boulevard and four along Admiralty Way.
- Installation of interpretative signage at the observation decks and along the walking trail to educate users about stormwater pollution prevention measures, native plants, and area wildlife.

The project scope is also shown on Attachment A, artistic rendering of completed project, and Attachment B, Preliminary Design Plans.

DISCUSSION

The Oxford Basin site occupies an area of approximately 10.7 acres and currently has a large retention pond that is inundated year-round with urban and stormwater runoff, high groundwater, and tidal inflows from Basin E. A 10-foot-high chainlink fence encloses the facility, and there are a variety of trees and shrubs along the basin's steep banks. The facility lacks recreational amenities and has little aesthetic appeal. Oxford Basin is primarily a flood control facility, detaining urban and stormwater runoff from the surrounding area (approximately 700 acres) of the Marina Del Rey Watershed. There are automatically controlled tide gates, which allow Oxford Basin to drain to the Marina when the water surface elevation in the Marina is lower than that in Oxford Basin. On occasion,

water in Basin E is allowed to enter the Oxford Basin through the gates for water recirculation purposes.

The Los Angeles Regional Water Quality Control Board (RWQCB) has identified Marina Beach ("Mother's Beach") and the Marina Del Rey Harbor Back Basins (Basins D, E, and F) as impaired water bodies. The jurisdictions within Oxford Basin's tributary drainage area are the Cities of Culver City and Los Angeles, the County of Los Angeles (County), and California Department of Transportation. Current Bacteria and Toxics Total Maximum Daily Load (TMDL) regulations call for an improvement to water quality in the Marina Del Rey Harbor back basins.

Basin Hydraulic Analysis

Two LACFCD storm drains discharge into Oxford Basin. Project No. 5243, constructed in 1969, was designed for the 10-year flow of 235 cubic feet per second (CFS), and Project No. 3872, constructed in 1972, was designed for the 10-year storm flows of 235 CFS. A new hydrology and storm routing analysis for Oxford Basin for a 50-year storm was conducted in August 2010, (Attachment D). The 50-year storm flow collected at Oxford Basin using the Watershed Modeling System and the Modified Rational Method was found to be 750 CFS. Based on initial water surface of 1.5 feet MSL in Oxford Basin and 2.7 feet MSL high tide water surface in the marina, routing the 50-year capital storm through the basin indicated that the maximum water surface in Oxford Basin would reach 4.9 feet MSL. While at this level, the discharge to the marina through the existing tide gates of 6-foot-by-6-foot reinforced concrete box and 81-inch diameter reinforced concrete pipe will be limited to 561 CFS. At an elevation of 4.9 feet MSL, the basin will have adequate storage capacity for 13.75 acre-feet. Under the 50-year capital storm event, the southerly and westerly perimeters of Oxford Basin will require a new parapet wall with the top-of-wall elevation at 8.0 feet MSL. This wall will provide the necessary freeboard to prevent flooding to the adjacent Parcel "OT" and along Washington Boulevard.

According to the hydraulic analysis conducted in 2010, when Oxford Basin reaches its maximum of 4.9 feet MSL, the low-lying subarea at the intersection of Oxford Avenue and Olive Street does not adequately drain into the Project 5243 Line "C" storm drain. This could lead to possible flooding above the property line within this reach for approximately 60 minutes before the basin water level recedes back to 3.8 feet MSL. In 2003, to address this flood hazard, check valves (Tideflex G-37) were installed on the connector pipes within the surrounding catch basins. However, one 7-foot-wide catch basin along Oxford Avenue could not be retrofitted with a check valve because it has a direct opening to the existing 6-foot-wide by 4-foot-high reinforced concrete box storm drain (Project 5243 Line "C").

The Project involves modification of the existing 7-foot-wide catch basin by separating the catch basin from Project No. 5243 and installing a check valve to isolate the potential backflow from the drain (See Attachment B, Sheet 3). Prior to forecasted storms, the basin is drained down to the lowest elevation possible, typically between -3.0 and -1.0 feet MSL. Any adverse affect on the lateral storm drain such as storm backflow along Oxford Avenue will be reduced. Therefore, based on the hydrology and reservoir routing analysis, the proposed improvements will alleviate flooding at the intersection of Olive Street and Oxford Avenue and no additional improvements are required on Oxford Avenue.

Water Circulation Operation

The Project will improve the water quality in Oxford Basin by increasing circulation and dissolved oxygen levels of the water within Oxford Basin. This will be accomplished by constructing a berm to direct flows around the basin and by revising the operation program of the tide gates to vary the water elevation between -2.0 and 1.5 feet MSL. This will facilitate better exchange of water between the Marina and the basin during high and low tides. Because the circulation will be powered by tidal action, the berm will have significantly lower maintenance requirements accomplishing the same goal as the mechanical circulation device included in the Project Concept Report.

The proposed berm structure will extend into the middle of Oxford Basin, separating incoming and outgoing flows and increasing circulation of water within Oxford Basin. The berm's function will be enhanced by strategic operation of the tide gates. For example, the west tide gate will be programmed to open during rising tides, sending water from Basin E into Oxford Basin, traveling upstream of the dividing berm. The east tide gate will be programmed to open during falling tides, forcing the water to circulate around the end of the berm and out of Oxford Basin into Basin E.

The top of the berm will be at 2.0 feet MSL and will be 2 feet wide. The berm will be planted with pockets of vegetation at an intermediate water elevation. The vegetation on the berm will potentially help to capture some of the pollutants in the water. See Attachment A for artistic renderings of the completed project.

Water Quality Enhancement

The proposed berm, modifications to the tide gate program, planting along the berm, landscaping on the embankment, and removal of deposited sediment will enhance circulation, increase oxygen levels in the water, remove pollutants, and improve the quality of water discharging from Oxford Basin.

To keep track of the improvements to the water quality, WMD will utilize data collected from the existing water quality monitoring system at station MdRH-5 in front of the tide gates, as well as the toxic monitoring station MdRH-B-2 in the middle of Basin E. Data collected from both stations will be used to evaluate the effectiveness of this Project.

Sediment Excavation

Removal of the contaminated sediment from Oxford Basin will ensure that this sediment is not contributing to concentrations of toxics, metals, or other pollutants of concern in the water within Oxford Basin prior to discharge to Basin E. A sediment and geotechnical study completed at Oxford Basin by URS Corporation in December 2011 identified evidence of elevated levels of hydrocarbons in sediment samples from the bottom of the basin. The report also identified the basin's perimeter to have levels of heavy metals above the thresholds for federal Resource Conservation and Recovery Act (RCRA) and California regulated (non-RCRA) hazardous material. Sediment removed from within the basin between elevation -3.0 MSL and elevation 1.0 MSL (approximately 2,700 CY) will be disposed at a Class III landfill and excavation material for retaining wall, access ramps and landscaping (approximately 300 CY) will need to be disposed at a Class I landfill. Staging, drying, and hauling of the excavated materials in the basin will be done as part of the contractor's soil management plan.

The landscaping work will require the excavation of approximately 6,200 CY of contaminated soil. Approximately 3,200 CY will be directed to a Class I landfill and 3,000 CY to a Class III landfill. This soil exceeds recommended agronomic thresholds, cannot be amended, and will need to be replaced for any type of planting to flourish. Biological assessments of the site have also recommended that approximately 150 non-native mature trees be removed to restore native habitat.

Based on the results and previous removal of material in the project area, the estimated total cost to remove the clean and hazardous soils is approximately \$1.4 million, \$300,000 for LACFCD funded work and \$1.1 million for County funded work.

Recreational and Aesthetic Improvements

The community neighboring Oxford Basin has expressed a strong desire to add recreational and aesthetically pleasing amenities to the area surrounding the basin.

Replacement of the sidewalk along Admiralty Way with a landscaped parkway/bio-swale and construction of an 8-foot-wide decomposed granite walking trail around Oxford Basin will significantly improve the recreational appeal of Oxford Basin. In addition, replacement

of existing vegetation with attractive, drought-tolerant native plants, installation of a 4-foot tall ornamental steel fence, construction of observation areas, interpretive signage, and improved wildlife friendly lighting will provide significant improvements to the site's aesthetics. See Attachment A for artistic renderings of the completed project.

The Oceana Del Rey retirement facility, a proposed multi-story housing development on Parcel OT (on the west side of Oxford Basin), is currently scheduled to begin construction in 2012. As part of their lease requirements, the developer has agreed to construct a walking trail and install landscaping in the adjacent space between the new complex and Oxford Basin. The trail and landscaping will be built to the same standard plans and architectural specifications as this Project. See Attachment C for plans of this proposed trail.

The Admiralty Way Settlement Repair Project is scheduled to begin in late 2012 and proposes a new temporary asphalt sidewalk, fencing, and grading into Oxford Basin. This sidewalk will be removed and replaced with a walking path as part of the Oxford Retention Basin Multiuse Enhancement Project.

RIGHT OF WAY AND MAINTENANCE

A construction easement from the City of Los Angeles will be required for the catch basin modification on Oxford Avenue and for construction of the walking trail along Washington Boulevard. No permanent easement or right-of-way acquisitions are required.

The County owns the Oxford Basin site, and the LACFCD, by agreement with the County, has unrestricted access to the site to maintain and operate its facilities thereon. This agreement stipulates that any construction projects initiated by the LACFCD on the Oxford Basin site must first be reviewed and approved by the DBH.

The maintenance responsibility of the non-flood control facilities on the Oxford Basin site, including the walking trail, landscaping, lighting, and other enhancements, has not been finalized. Watershed Management Division will facilitate the establishment of a Memorandum of Understanding (MOU) to be agreed upon by the County DBH, LACFCD, and/or the Department of Public Works for the maintenance of these improvements.

ENVIRONMENTAL DOCUMENT AND PERMIT REQUIREMENTS

Programs Development Division (PDD) has secured the services of Chambers Group as environmental consultant to prepare all required environmental documents. The consultant has determined the Project will require at least a Mitigated Negative Declaration, and that it may be necessary to prepare an Environmental Impact Report

depending comments from the public review period from the constituents, regulatory agencies, and the general public. The Initial study will include Biological Resources, Cultural Resources, Hazards, and Hazardous Materials.

The Project is located within the coastal zone and must comply with the County-certified Local Coastal Program (LCP) for Marina Del Rey pursuant to Section 30519.5 of the Coastal Act. In addition, a Clean Water Act Permit for Section 401 from RWQCB and a Nationwide Permit from the United States Army Corps of Engineers will be required. The California Department of Fish and Game will require compliance with Section 1602 for any modifications made to Oxford Basin.

PROJECT CONSTRUCTABILITY AND ISSUES

High groundwater is expected during high tide. Dewatering will be required during excavation within the basin and will be subject to RWQCB regulations. Noise levels may need to be addressed due to construction activities that impact the bird nesting season.

All excavation and sediment disposal included in this Project will be required to comply with hazardous waste discharge requirements and the South Coast Air Quality Management District Rule 1166, Contaminated Soil Mitigation Plan. The trucking of material will be constant during grading and excavation, a truck route plan will need to be approved by the City of Los Angeles.

COMMUNITY OUTREACH

Public Works has been in contact with several stakeholders during the planning of this project. A chronological history of meetings with stakeholders can be seen on Attachment E.

TRAFFIC

A traffic detour plan will be required in order to allow the ingress and egress of heavy equipment to perform excavation operations at Oxford Basin. Detour and/or traffic control measures will also be required during perimeter construction activities.

UTILITIES

No utility relocations are anticipated for this Project.



Project Details

Oxford Retention Basin


- Primarily a flood control facility
- Unique salt marsh habitat


Multi-Benefit Project


- Flood risk management
- Improve water quality
- Improve habitat
- Improve aesthetics and recreational opportunities
























Gateway Area (proposed)














Benefits to Community

- Flood Risk Management
- Recreation opportunities
 - Walking/Jogging trail
 - Bicycle path (existing)
 - Observation areas
 - Bird watching
- Improved aesthetics
 - Enhanced fencing
 - Landscaping
 - Lighting
 - Signage
- Environmental benefits
 - Water quality
 - Habitat





Similar Site: Ballona Freshwater Lagoon



Similar Plant Palette – Madrona Marsh









Fencing Options











Similar Fence: Bora Bora Way



Similar Fence Pilasters



Example of Seat Wall and Skate Stops




Example of Colored Concrete









Chromix C-31 Shadow Slate

> Chromix C-24 Charcoal

Un-Colored Concrete






Example of Overlook



Example Site Features











SIGN LOCATION PLAN



OXFORD BASIN SIGNAGE (Version A)








Loop Map Sign on Pilaster




Regulatory Sign on Fence



Dog Sign on Post







Wayfinding Sign on Post



Wayfinding Sign on Post

WAYFINDING SIGN LEGEND (VERSION A)











OXFORD BASIN

OXFORD BASIN

OXFORD BASIN



















OXFORD BASIN NATURE LOOP

WE INVITE YOU TO EXPLORE THE OXFORD BASIN NATURE LOOP AND DISCOVER ITS UNIQUE AND DIVERSE HABITAT. SOME OF THE SPECIES FOUND AT THE BASIN ARE SENSITIVE AND ARE ENDANGERED. WE ENCOURAGE YOU TO FIND MORE ABOUT THE ANIMALS AND THE PLACE THEY CALL HOME AS YOU COME ENCOUNTER OUR FIVE OBSERVATION AREAS. FOLLOW THE SIGNS AS THEY WILL SHOW YOU THE TRAIL DIRECTION AND THE MILES YOU HAVE TRAVERSED.





OXFORD BASIN






Loop Map Sign on Pilaster

BASIN







Please see that your pets refrain from littering.

All pets must be on a leash not more than six feet long at all times, and are prohibited in planter areas. Violating owners will be cited. (LACC 19.12.1370)

OXFORD BASIN



SENSITIVE HABITAT AREA DO NOT ENTER



RESIDENTS OF OXFORD BASIN

- Mallard
- Anna's Hummingbird
- Yellow-Rumped Warbler
- **Black Phoebe**
- **Cheekspot Goby**
- **Mosquito Fish**
- **Yellow-Rumped Warbler**
- **Arrow Goby**
- **Honey Bee**
- **Monarch Butterfly**
- California Mud Snail
- **Margined Spur-Throated** Grasshopper



Anas platyrhynchos / Mallard

Calypte anna / Anna's Hummingbird

Setophaga coronata I Yellow-rumped Warbler



Ilypnus gilberti / Cheekspot Goby

Gambusia affinis / Mosquitos Fish



Apis / Honey Bee



Danaus plexippus / Monarch Butterfly



Cerithidea californica / California Mud Snail



Atherinops affinis / Topsmelt





Margined Spur-throated Grasshopper

WILDLIFE: Can You Find Me?

LEAST TERN





The Least Tern arrives at its breeding grounds in late April. Nests are situated on barren to sparsely vegetated places near water, normally on sandy or gravelly substrates. Nests typically house two or three, but it is not rare to consist of either one or four eggs. Both female and male incubate the eggs for a period of about three weeks, and both parents tend the semiprecocial young Young birds can fly at age four weeks.



OXFORD BASIN MAP





Sayornis nigricans / Black Phoebe











THE PLANT **COMMUNITIES OF OXFORD** BASIN

This is a wetland plant community that occurs along the coast. Salicornia viginica, Pickelweed is a common species in this community and is tolerant of salt water. Other plants that are often seen in this community include Alkali Heath, Saltgrass, and Southwest Spiny Rush.

This habitat occurs along the California coast from Ventura County to San Diego County and is characterized by low-growing, aromatic plants. Two common coastal sage scrub plants are Artemesia californica, California Sagebrush, and Encelia californica, California Encelia (shown below). Other plants that are often seen in this community include California Buckwheat, Lemonade Berry, and Purple Needlegrass.

This dense plant community is important browsing and foraging habitat for many riparian wildlife species. Some common plants in this community include the small tree Salix exigua, Sandbar or Narrow Leaf Willow. Other plants that are often seen in this community include California Blackberry, Desert Grape, Mexican Elderberry, Mulefat, and California Wild Rose.



Salt Grass

Salicornia virginica I

Common Pickleweed

Distichlis spicata /



Purple Neddlegrass



Artemisia californica I

California Sagebrush





Rubus ursinus I California Blackberry

Desert Grape





What is a **NATIVE PLANT?**

Baccharis salicifolia I Mulefat

Salix exigua I Narrow Leaf Willow



Juncus acutus leopoldii I Southwestern Spiny Rush



Frankenia salina I Alkali Heath



California Encelia

COASTAL SAGE

SCRUB

WILLOW SCRUB

COASTAL SALT MARSH














THE HISTORY OF OXFORD BASIN



OXFORD BASIN











Recent Activity

- Project Design: 100% Plans currently under review
- Environmental document scheduled for public review in April 2013
- Permit applications submitted in September 2012
 - Army Corps, CA Fish & Wildlife, Regional Water Board









County of Los Angeles Department of Public Works dpw.lacounty.gov

JOSHUA SVENSSON, P.E.

Watershed Management Division

(626) 458-7157 jsvensson@dpw.lacounty.gov





County of Los Angeles Department of Public Works dpw.lacounty.gov

MENERVA ARIKI, P.E.

Watershed Management Division


(626) 458-4316 mariki@dpw.lacounty.gov



LANDSCAPE IMPROVEMENTS


FOR

OXFORD RETENTION BASIN MULTI-USE ENHANCEMENT PROJECT



SHEET INDEX:	
SHEET#	TITLE
LS-1.1 LS-1.2	LANDSCAPE PLAN INDEX & KEY MAP NOTES, ABBREVIATIONS, CONSTRUCTION & MATERIALS LEGEND
LS-2.1 LS-2.2 LS-2.3 LS-2.4	CONSTRUCTION PLAN CONSTRUCTION PLAN CONSTRUCTION PLAN CONSTRUCTION PLAN
LS-2.5 LS-2.6	ENLARGEMENTS SECTIONS
LS-2.7 LS-2.8 LS-2.9 LS-2.10 LS-2.11	CONSTRUCTION DETAILS CONSTRUCTION DETAILS CONSTRUCTION DETAILS CONSTRUCTION DETAILS CONSTRUCTION DETAILS
LS-3.0 LS-3.1 LS-3.2 LS-3.3 LS-3.4 LS-3.5 LS-3.5	IRRIGATION LEGENDS HYDROZONE PLAN IRRIGATION PLAN IRRIGATION PLAN IRRIGATION PLAN IRRIGATION PLAN IRRIGATION DETAILS IRRIGATION DETAILS
LS-4.0 LS-4.1 LS-4.2 LS-4.3 LS-4.4	PLANTING LEGEND & NOTES PLANTING PLAN PLANTING PLAN PLANTING PLAN PLANTING PLAN PLANTING PLAN PLANTING DETAILS







OXFORD RETENTION BASIN MULTI-USE ENHANCEMENT PROJECT

COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC WORKS

LANDSCAPE PLAN INDEX & KEY MAP

LS-1.1

FCC0001176 PCA EF21507000

SHEET 1 OF 27

MATERIALS LEGEND:

SYMBOL	DESCRIPTION	SIZE	COLOR/MANUFACTURER	FINISH	DETAIL REF.
	CONCRETE PAVING (PCC)	4" PEDESTRIAN 6" VEHICULAR	NATURAL GRAY	BROOM FINISH	DET B / LS-2.8
//////	SEAT WALL (PCC)	18" X 24"	NATURAL GRAY, APPLY TOPCOAT GRAFFITI PREVENTION MATERIAL BY KRYSTALKOAT OR APPROVED EQUAL.	LIGHT SAND- BLAST	DET A / LS-2.10
	CONCRETE PAVING, (PCC) WITH INTEGRAL COLOR	6"	INTEGRAL COLOR: (C-24) CHARCOAL, CHROMIX ADMIXTURE WITH A WATERBORNE, LOW VOC, ENVIRONMENTALLY SOUND, CLEAR CURING COMPOUND AND SEALER, CURESEAL-W, BOTH BY L.M. SCOFIELD COMPANY OR APPROVED EQUAL(S).	BROOM FINISH	DET B / LS-2.8
	CONCRETE PAVING, (PCC) WITH INTEGRAL COLOR	6"	INTEGRAL COLOR: (C-31) SHADOW SLATE, CHROMIX ADMIXTURE WITH A WATERBORNE, LOW VOC, ENVIRONMENTALLY SOUND, CLEAR CURING COMPOUND AND SEALER, CURESEAL-W, BOTH BY L.M. SCOFIELD COMPANY OR APPROVED EQUAL(S).	BROOM FINISH	DET B / LS-2.8
	CONCRETE HEADER (PCC)	6" X 12"	NATURAL GRAY	BROOM FINISH	DET D / LS-2.8
	DECOMPOSED GRANITE, (D.G.)	4"	GOLD WITH STABILIZER	SMOOTH SURFACE	DET A / LS-2.8
	COMPOSITE WOOD DECKING	2" THICK	FIRE DEFENSE, COLOR: 'SADDLE, WEATHERED', BY TREX OR APPROVED EQUAL.		DET D / LS-2.7
	DECK RAILING, TUBULAR STEEL	3'-6"'	COLOR: BLACK		DET A / LS-2.7
	TUBULAR STEEL FENCE	3-4'	COLOR: BLACK		DET B / LS-2.9
	TUBULAR STEEL FENCE	7-8'	COLOR: BLACK		DET A / LS-2.9
+	TUBULAR STEEL DECORATIVE PANEL	3-4'	COLOR: BLACK		DET E / LS-2.10
	SINGLE GATE, TUBULAR STEEL	4'	COLOR: BLACK		DET D / LS-2.10
X	DOUBLE GATE, TUBULAR STEEL	8'	COLOR: BLACK		DET D / LS-2.9
	SLIDING GATE, TUBULAR STEEL	8'	COLOR: BLACK		DET H / LS-2.9
	LITTER RECEPTACLE	32 GALLON	CARNIVAL, MODEL # CRTR-32-P-LID-D-SF, BLACK POWDER COATED, BY THOMAS STEELE OR APPROVED ALTERNATE.		DET E / LS-2.8 and LS-2.11
	INTERPRETIVE SIGN	-	SIGN, MODEL # SP1218, BLACK POST,WITH 2'x3' EXTERIOR dHPL 1/2" GRAPHIC PANEL BY FOSSIL INDUSTRIES OR APPROVED EQUAL.		DET G / LS-2.8
	BICYCLE U SHAPE RACK WITH LEAN BAR	SEE DETAIL	BICYCLE RACK, MODEL # UX200-LB-IG-P, BLACK COLOR POWDER COAT FINISH, BY BELSON OUTDOORS OR APPROVED ALTERNATE BIKE RACK.		DET F / LS-2.8
	BOLLARD	4.5" DIA.	BOLLARD, MODEL # BOL450-IG-P, LEXINGTON BLACK COLOR POWDER COAT FINISH, BY BELSON OUTDOORS OR APPROVED ALTERNATE.		DET J / LS-2.8
	PET WASTE STATION	-	DOGIPOT MODEL # DP-1010, GREEN, BY BELSON OUTDOORS OR APPROVED ALTERNATE.		DET I / LS-2.8
	BENCH	8'	CARNIVAL, MODEL #CRB-8-P, WITH CENTER ARMREST AND HORIZONTAL STRAPS, BLACK COLOR POWDER COATED FINISH, BY THOMAS STEELE OR APPROVED ALTERNATE.		DET H / LS-2.8
	FLAT BENCH	8'	CARNIVAL, MODEL #CRF-8-CA-VS-P, WITH ARMRESTS AND CENTER ARMREST, BLACK COLOR POWDER COATED FINISH, BY THOMAS STEELE OR APPROVED ALTERNATE.		DET D / LS-2.7
	PILASTER, SPLITFACE CMU W/ CAP	VARIES	8" x 8" x 16" SPLIT FACE CONCRETE BLOCK, COOL GRAY COLOR, BY ANGELUS BLOCK OR APPROVED EQUAL. PRECAST CONCRETE CAP, MODEL #Q-E13PC, COLOR NATURAL GREY AND FINISH T3 - SANTA FE SANDBLAST BY QUICKCRETE OR APPROVED EQUAL.		DET B / LS-2.7
	BOLLARD LIGHT				REFER TO

NOTE: REFER TO GREENBOOK SECTION 303-7 FOR INTEGRAL COLORED CONCRETE

GENERAL CONSTRUCTION & REMOVAL NOTES:

- 1. PLANS ARE DIAGRAMMATIC. THE CONTRACTOR SHALL BRING TO THE ATTENTION OF THE ENGINEER ANY PERCEIVED DISCREPANCY BEFORE THE START OF CONSTRUCTION.
- 2. THE CONTRACTOR SHALL LAY OUT FORMWORK AND OBTAIN APPROVAL FROM THE ENGINEER PRIOR TO PLACING CONCRETE, TYPICAL.
- 3. CONTRACTOR SHALL PROVIDE EXPANSION JOINTS WITH SEALANT WHERE PAVING ABUTS CURBS, BUILDINGS AND COLUMNS, STRUCTURES, AND EXISTING STRUCTURES.
- 4. CONTRACTOR SHALL SUBMIT SAMPLES FOR COLORED CONCRETE. CONTRACTOR TO PROVIDE 3'X3' SAMPLES IN FIELD FOR LANDSCAPE ARCHITECT'S REVIEW AND APPROVAL BY THE ENGINEER PRIOR TO COMMENCING WORK. (SAMPLES TO INCLUDE COLOR AND FINISH).
- 5. ALL EXISTING ELEMENTS NOT DESIGNATED TO BE REMOVED SHALL BE PROTECTED IN PLACE. REFER TO SITE PLAN EXISTING FACILITIES.
- 6. EXISTING SURVEY MONUMENTS TO REMAIN. PRIOR TO REMOVAL (IF NECESSARY), COORDINATE WITH LA COUNTY SURVEY DIVISION (DAVID FARRELL, 626-458-5144), TO PERPETUATE THE MONUMENTS.

CONSTRUCTION LEGEND:

- 1. SEAT WALL (PCC), 18" X 24", POURED IN PLACE CONCRETE MIX 560-C-3250, NATURAL GRAY. SEE SHEET LS-2.10, DETAIL A.
- 2. CONCRETE PAVING (PCC) 6" THICK, MIX 520-C-2500, WITH INTEGRAL COLOR CHARCOAL (C-24) BY L.M. SCOFIELD COMPANY OR APPROVED EQUAL. SEE SHEET LS-2.8, DETAIL B.
- 3. CONCRETE PAVING (PCC) 6" THICK, MIX 520-C-2500, WITH INTEGRAL COLOR SHADOW SLATE (C-31) BY L.M. SCOFIELD COMPANY OR APPROVED EQUAL. SEE SHEET LS-2.8, DETAIL B.
- 4. CONCRETE PAVING (PCC) 4" THICK, MIX 520-C-2500, NATURAL GRAY. SEE SHEET LS-2.8, DETAIL B.
- (5.) CURB RAMP, REFER TO CALTRANS RSP A88A, CASE G.
- (6.) CONCRETE HEADER (PCC) 6" X12", SEE SHEET LS-2.8, DETAIL D.
- 7. DECOMPOSED GRANITE W/ STABLIZER, COLOR TO BE GOLD. SEE SHEET 20 (LS-2.8), DETAIL A.
- (8.) FENCE ON WALL, TUBULAR STEEL 3'. SEE SHEET LS-2.9, DETAIL C.
- (9.) FENCE ON WALL, TUBULAR STEEL 7'. SEE SHEET LS-2.9, DETAIL A.
- (10.) FENCE ON GRADE, TUBULAR STEEL 4'. SEE SHEET LS-2.9, DETAIL G.
- (11.) FENCE ON GRADE, TUBULAR STEEL 8'. SEE SHEET LS-2.9, DETAIL F.
- (12.) DOUBLE GATE, TUBULAR STEEL 8'. SEE SHEET LS-2.9, DETAIL D.
- 13.) FENCE ON SLOPE, TUBULAR STEEL 8'. SEE SHEET LS-2.10, DETAIL C.
- (14.) SLIDING GATE, TUBULAR STEEL 8'. SEE SHEET LS-2.9, DETAIL H.
- 15.) LITTER RECEPTACLE. REFER TO MATERIALS LEGEND (THIS SHEET) FOR MAKE/MODEL INFO. SEE SHEET LS-2.8, DETAIL E. (TOTAL 10)
- 16.) FLAT BENCH. REFER TO MATERIALS LEGEND (THIS SHEET) FOR MAKE/MODEL INFO. SEE SHEET LS-2.7, DETAIL D. (TOTAL 4)
- BENCH. REFER TO MATERIALS LEGEND (THIS SHEET) FOR MAKE/MODEL INFO. SEE SHEET LS-2.8, DETAIL H. (TOTAL 2)
- 18.) BICYCLE U SHAPE RACK W/ LEAN BAR. REFER TO MATERIALS LEGEND (THIS SHEET) FOR MAKE/MODEL INFO. SEE SHEET LS-2.8, DETAIL F. (TOTAL 3)
- 19.) BOLLARD. REFER TO MATERIALS LEGEND (THIS SHEET) FOR MAKE/MODEL INFO. SEE SHEET LS-2.8, DETAIL F. (TOTAL 2)
- 20. PET WASTE STATION. REFER TO MATERIALS LEGEND (THIS SHEET) FOR MAKE/MODEL INFO. SEE SHEET LS-2.8, DETAIL I. (TOTAL 1)
- 21. INTERPRETIVE SIGN. REFER TO MATERIALS LEGEND (THIS SHEET) FOR MAKE/MODEL INFO. SEE SHEET LS-2.8, DETAIL G. AND LS-2.11 (TOTAL 5)
- (22.) BIOSWALE, SEE SHEET LS-2.10, DETAIL B.
- (23.) PILASTER, SPLIT FACE CMU W/ CAP. SEE SHEET LS-2.7, DETAIL B.
- (24) BIKE PATH, REFER TO SHEET LS-2.6.
- (25.) TUBULAR STEEL, DECORATIVE PANEL, SEE SHEET LS-2.10, DETAIL E.
- (26.) LIGHT. REFER TO PLAN E FOR ELECTRICAL.
- 27. COMPOSITE WOOD DECKING. REFER TO MATERIALS LEGEND (THIS SHEET) FOR MAKE/MODEL INFO. SEE SHEET LS-2.7, DETAIL D.
- (28.) DECK RAILING, TUBULAR STEEL, SEE SHEET LS-2.7, DETAIL A.
- (29) RETAINING WALL PER PLAN RD.
- (30.) IMPORTED TOP SOIL TO 24" DEEP
- (31.) SINGLE GATE, TUBULAR STEEL 4', SEE DETAIL D, SHEET LS-2.10
- (32.) WAYFINDING SIGNAGE, SEE SHEET LS-2.7 DETAIL B AND SHEET LS-2.11

ABBREVIATION LEGEND:

& @ & Ø #	AND AT CENTERLINE DIAMETER NUMBER OR POUNDS	N N.I.C. NO. NOM. N.T.S.	NORTH NOT IN CONTRACT NUMBER NOMINAL NOT TO SCALE
AC ASPHAL A.D. AREA D AGG. ALT. ALTERI ARCH. ASPH. AVE.	TIC CONCRETE PRAIN AGGREGATE	O.C. O.D. P.A. P.B. PERF. P.L. PLYWD. P.O.C.	ON CENTER OUTSIDE DIAMETER PLANTING AREA PULL BOX PERFORATED PROPERTY LINE PLYWOOD POINT OF CONNECTION
B.C. B.C.R. BLDG.	BOTTOM OF CURB OR BEGINNING OF CURVE BEGINNING CURVE RADIUS BUILDING	P.P. PREFAB. PROP. PR. REG. P.T.	POWER POLE PREFABRICATED PROPERTY PRESSURE REGULATOR PRESSURE TREATED
BLVD. B.M. B.W.	BOULEVARD BENCH MARK BOTH WAYS	PVMT. Q.C.	PAVEMENT QUICK COUPLER
C.B. C.J. C.L. CLR. C.M.U. C.O. CONC. CONT. CTR.	CATCH BASIN CONTROL JOINT CHAIN LINK CLEAR CONCRETE MASONRY UNIT CLEAN OUT CONCRETE CONTINUOUS, CONTINUED CENTER	R. RAD. R.C.V. RD. REINF. REV. R.O.W. R.U. RWD.	RISERS OR RADIUS RADIUS REMOTE CONTROL VALVE ROAD REINFORCED REVISED OR REVISION RIGHT OF WAY RELOCATE UTILITY REDWOOD
DBL. DEPT. DET. D.F. D.G. DIA. DIM. DPW DWG. DWP	DOUBLE DEPARTMENT DETAIL DOUGLAS FIR DECOMPOSED GRANITE DIAMETER DIMENSION DEPARTMENT OF PUBLIC WORKS DRAWING DEPARTMENT OF WATER AND POWER	S. SCE. SCH. S.D. SEC. SHT. SIM. SPECS. SPR. SQ. ST.	SOUTH SOUTHERN CALIFORNIA EDISO SCHEDULE STORM DRAIN SECTION SHEET SIMILAR SPECIFICATION SPRINKLER SQUARE STREET
E. E.C.R. EXIST. EA. E.J. EL. OR ELEV. ELEC. ENCL. EQ. EQUIP. EXP.	EAST END CURVE RADIUS EXISTING EACH EXPANSION JOINT ELEVATION ELECTRICAL ENCLOSURE EQUAL, EQUALLY EQUIPMENT EXPANSION	STL. SYM. T. T.C. T.O.D. TEL. TEMP. T.G. T.G. T.G. T.P.	STREET STEEL SYMBOL TREADS TOP OF CURB TOP OF DRAIN TELEPHONE TEMPORARY TOP OF GRADE TONGUE AND GROOVE TOP OF PAVEMENT
F.G. F.H. F.F.E. F.L. F.S. FT. FTG. GA. GALV. G.V. GAL. G.W.	FINISHED GRADE FIRE HYDRANT FINISHED FLOOR ELEVATION FLOW LINE FINISHED SURFACE FEET OR FOOT FOOTING GAUGE GALVANIZED GATE VALVE GALLON GUY WIRE	T.S. T.W. OR T.O.W. TYP. U.O.N. V. V.B. VERT. V.I.F. VOL.	TUBE STEEL TOP OF WALL TYPICAL UNLESS OTHERWISE NOTED VALVE VALVE BOX VERTICAL VERIFY IN FIELD VOLUME
H.B. HOR. OR HORIZ. H.P. HT. OR HGT.	HOSE BIBB HORIZONTAL HIGH POINT HEIGHT	W. W/ WD. W.H. W.I.	WEST OR WIDE OR WATER WITH WOOD WEEP HOLE WROUGHT IRON
I.D. INV. IRR.	INSIDE DIAMETER INVERT IRRIGATION	W.M. W/O WP. WPJ.	WATER METER WITHOUT WATERPROOF (ING) WEAKEN PLANE JOINT
JT.	JOINT	WT. W.W.F. W.W.M.	WEIGHT WOVEN WIRE FABRIC WELDED WIRE MESH
L. LAB. LBS. LT.	LONG OR LENGTH LABORATORY POUNDS LIGHT	Y.D.	YARD DRAIN
MATL. MAX. MECH. MFR. M.H. MIN. MISC.	MATERIAL MAXIMUM MECHANICAL MANUFACTURER MANHOLE MINIMUM MISCELLANEOUS	MAY NOT HAVE I	ATIONS ON THE DRAWINGS PERIODS AS PART OF THE DELETION OF PERIOD ER MEANING.

PLAN LS

CALL 8-1-1 TOLL FREE
2 workings days before you dig

DESCRIPTION

ANDSCAP

TUREN

ZUREN

J-14-1

Date

OF CALIF

PROJECT LANDSCAPE ARCHITECT

REVISIONS


OXFORD RETENTION BASIN
MULTI-USE ENHANCEMENT PROJECT
NOTES, ABBREVIATIONS, CONSTRUCTION &
MATERIALS LEGEND


COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC WORKS


LS-1.2


FCC0001176 PCA EF21507000


SHEET 2 OF 27






























SIGNAGE GRAPHICS ARE FOR REFERENCE ONLY. CONTRACTOR SHALL SUBMIT SHOP DRAWINGS TO COUNTY FOR FINAL REVIEW

ARTWORK SHALL BE PROVIDED BY THE COUNTY. SIGN AND GRAPHICS SHALL BE FABRICATED AND INSTALLED BY THE CONTRACTOR.

AND APPROVAL.



ON POSTS.

CALL 8-1-1 TOLL FREE
2 workings days before you dig

DATE MK DESCRIPTION
REVISIONS

REGULATORY SIGN

SENSITIVE HABITAT AREA
DO NOT ENTER

* SIGN TO BE MOUNTED TO FENCE

PICKETS FACING AWAY FROM BASIN

DOG SIGN

Please see that your pets refrain

Violating owners will be cited.

OXFORD BASIN

* SIGN TO BE MOUNTED TO DOG POST

(LACC 19.12.1370)

OXFORD BASIN LOOP SIGN

WALK THE LOOP

OXFORD BASIN

* SIGN TO BE MOUNTED TO PILASTER

A SIGNAGE POST

LERED LANDSCAPE ARCHITECTURE AND THE OF CALLIFORNIA AND THE OF CALLIFORNIA

FCC0001176

OXFORD RETENTION BASIN
MULTI-USE ENHANCEMENT PROJECT

COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC WORKS

NTS

CONSTRUCTION DETAILS

01176 PCA EF21507000 SHEET 13 OF 27

S: 1/2" = 1'-0"


PLAN LS


* ALL SIGNS ON CMU PILASTERS EXCEPT FOR SIGNS B & E TO BE ON POSTS.


REFER TO DET. A ON THIS SHEET


(B) SIGNAGE LOCATIONS AND GRAPHICS


		IRRIGATION SPRINKLER LEGEND IRRIGATION EQUIP	MENT LEGEND
			JFACTURER MODEL/TYPE SIZE DETAIL
	IRRIGATION INSTALLATION NOTES: 1. TRENCHING OPTION: CONTRACTOR HAS AS AN OPTION TO INSTALL LATERAL	A 12" POP-UP SHRUB ROTOR RAINBIRD OR APPROVED EQUAL 5012-PC-SAM 5000-MPR-25 25' 1.0,2.0 45 QTR./HLF I/SHT3.6 REMOTE CONTROL VALVE OR APPROVED EQUAL	AINBIRD 150-PEB-PRS-D 1.5" C/SHT3.6
	IRRIGATION LINES UTILIZING A TRENCHLESS TECHNIQUE (PULLED IN) WHERE POSSIBLE.	REMOTE CONTROL DRIP VALVE W/ INLINE WYE REMOTE CONTROL DRIP VALVE W/ INLINE W/ INLINE WYE REMOTE CONTROL DRIP VALVE W/ INLINE W	AINBIRD XCZ-100-COM U/FD-101-TURF 1" D/SHT3.6
	 CONTRACTOR SHALL FIELD VERIFY ALL EXISTING CONDITIONS AND DIMENSIONS AND SHALL NOTIFY THE ENGINEER OF ANY DISCREPANCIES PRIOR TO START OF CONSTRUCTION. 	OKAPPROVEDEQUAL OKAPPROVEDEQUAL SOLO DO SAME TO SAME	AINBIRD 33 DLRC 3/4" E/SHT3.6
	3. CONTRACTOR TO VERIFY LOCATIONS OF ALL EXISTING TREES AND OTHER PLANTS IN THE AREAS OF WORK PRIOR TO START OF CONSTRUCTION.	I /AAN I QUDUD DOTOD ON DIRED I RAINKIRU I FAAA A BA AAN I FAAA NABA AF I DEU I 1/1/2/11 //A I //III I I/KIII/A A HA III/A I E VALVE	IBCO T-113-K LINE SIZE J/SHT3.6
	4. INSTALL PVC SCHEDULE 40 CONDUIT UNDER EXISTING PAVING WHEREVER NECESSARY TO "RUN" CONTROL WIRES. INSTALL CONTROL WIRES A MINIMUM 24"	SHRUB ROTOR ON RISER RAINBIRD OR APPROVED EQUAL 5000-S-PC-SAM 5000-MPR-35 35' 1.9,3.8 45 QTR./HLF F/SHT3.6 BALL VALVE	BI SCH.80 TRUE UNION LINE SIZE L/SHT3.7
	BELOW FINISH GRADE AND 36" UNDER VEHICULAR ROADWAY. 5. ALL VERTICAL CHANGES IN MAINLINE PIPE DIRECTION SHALL BE DONE WITH THE USE	A1 SHRUB ROTOR ON RISER RAINBIRD OR APPROVED EQUAL 5000-S-FC-SAM 5000-MPR-25 25' 3.82 45 FULL F/SHT3.6 POINT OF CONNECTION - TIE INTO EXISTING BACKFLOW AND INSTALL NEW ENCLOSURE	SEE PLAN H/SHT3.6
	OF 45 DEGREE ELBOWS. 6. LATERAL SUPPLY LINES FROM THE VALVE TO THE FIRST HEAD SHALL BE ONE SIZE	I IDAL I CUDUD DOTOD ON DICED I RAINBIRD I FOOG ANA FOOG MEDICO I FOO I FOOG MEDICO I	AINBIRD ESP-LXD-ETC-LX-LXMM SEE PLAN A/SHT3.6
	LARGER THAN THE VALVE, UNLESS OTHERWISE NOTED. 8. WATER METER IS EXISTING. CONTRACTOR SHALL FIELD VERIFY THE EXACT	I IMAL I CUDUD DOTOD ON DICED I MANGRICU I RAAA A BA AAAA I BAAA ABA ABA ABA ABA ABA	RISWALD 2100 SERIES 2" B/SHT3.6
	LOCATIONS OF THE METER(S). CONTRACTOR SHALL VERIFY THE P.O.C. LOCATION AND NOTIFY THE ENGINEER FOR ANY DISCREPANCIES. SEE PLANS FOR AVAILABLE WATER PRESSURE AT THE P.O.C. AND WATER PURVEYOR'S INFORMATION.		AINBIRD EM 1.5B W/SD210TURF 1.5" B/SHT3.6
	9. REPAIR ALL EXISTING MATERIALS DAMAGED OR EXPOSED BY NEW IRRIGATION INSTALLATION WORK OR BY ANY OTHER CONSTRUCTION WORK, MATCH EXISTING		ATERMARK WEM-B W/SD210TURF O/SHT3.7 PROVED EQUAL O/SHT3.7
	ADJACENT WORK IN TEXTURE AND COLOR. 10. ALL QUICK COUPLING VALVES SHALL BE INSTALLED IN LOCK LID VALVE BOXES. MARK	ROTARY NOZZLE ON RISER RAINBIRD OR APPROVED EQUAL PA-8S-PRS R13-18 13'-18' 0.80MAX 30 QTR./HLF G/SHT3.6 ——— LATERAL LINE	SEE SPECS SEE PLAN Q/SHT3.7
·	ALL BOXES Q.C.V. WITH EPOXY PAINT. 11. IRRIGATION HEADS SHALL BE PROPERLY POSITIONED TO ALLOW STANDARD	TREE BUBBLER RAINBIRD OR APPROVED EQUAL RWS-B-C-1401 1401 0.50 30 FULL M/SHT3.7 LATERAL LINE ON-GRADE STAKE 10'OC	SEE SPECS SEE PLAN G/F/SHT3.6
	OPERATION, RETRACTION, AND SHALL BE ADJUSTED SO THERE IS NO OVERPSRAYING ONTO ADJACENT SIDEWALKS, PAVEMENT(S), AND ROADWAYS.	© DRIP EMITTER ON FLEX RISER GPH OR APPROVED EQUAL GPST-1 W/GIH-12 1GPH 30 FULL N/SHT3.7 MAIN LINE	SEE SPECS 2.5" Q/SHT3.7
	12. CONTRACTOR SHALL MAKE ALL NECESSARY ADJUSTMENTS TO ENSURE THAT ALL COMPONENTS OF THE IRRIGATION SYSTEM PERFORM PROPERLY DURING CONSTRUCTION AND MAINTENANCE PERIODS.	PIPE SLEEVE FOR CONTROLLER WIRES.	SEE SPECS 3" Q/SHT3.7
	13. CONTRACTOR SHALL PROVIDE AND INSTALL FLOW METER(S) AND MASTER CONTROL VALVE(S) FOR ALL PROPOSED AUTOMATIC IRRIGATION CONTROL SYSTEM(S) AS	==== PIPE SLEEVE	SEE SPECS 2x PIPE SIZE P/Q SHT3.7
	SHOWN ON PLANS. INSTALLATION SHALL BE PER DETAILS AND MANUFACTURER'S RECOMMENDATIONS. CONTRACTOR SHALL BE RESPONSIBLE TO PROGRAM THE AUTOMATIC IRRIGATION CONTROLLER(S) SO THE SYSTEM SHALL BE FULLY OPERATION TO DETECT MAIN AND LATERAL LINE BREAKAGE.		RAINBIRD MAXICABLE W/ LSP-1 500' ON CENTER N/A
	14. ADJUST LOCATION OF IRRIGATION HEADS AS NECESSARY TO MINIMIZE SPRAY INTERFERENCE AGAINST OBSTRUCTIONS (CONCRETE WALLS, TELEPHONE AND POWER POLES, TREES, ETC.).	VALVE SYMBOL 16 3 - STATION NUMBER	
	15. ADJUST ALL ADJUSTABLE ARC NOZZLES AS NECESSARY TO AVOID UNDER-SPRAY OF PLANTING AREAS AND OVER-SPRAY OF WALLS AND SIDEWALKS.	1-1/4" VALVE SIZE	
ш	16. CONTRACTOR SHALL ADJUST POSITION OF ROTOR IRRIGATION HEADS IN FIELD, AS NECESSARY, TO MAINTAIN 10' MIN. DISTANCE FROM TRUNKS OF TREES.	IRRIGATION SCHEDULE AND PRESSURE CALCULATION GPM	
DA	17. FOLLOWING IRRIGATION HEAD INSTALLATION, ADJUST RADIUS THROW TO CONFORM TO SITE CONDITIONS.	IRRIGATION CONTROLLER RUN TIMES	
CHUNG	18. INSTALL NEW ELECTRIC IRRIGATION CONTROLLERS WHERE SHOWN ON PLAN. EXTEND ELECTRICAL CONDUIT AND WIRES FROM ELECTRICAL P.O.C. SHOWN ON PLAN TO THE CONTROLLER AND MAKE CONNECTIONS AS NECESSARY TO PROVIDE AN OPERATIONAL ELECTRICAL AUTOMATIC IRRIGATION SYSTEMS.	POC or Controller Figure	
BY KHAI	19. ON ALL CONTROLLERS 50 FEET OR MORE FROM THE CIRCUIT BREAKER, PROVIDE AND INSTALL A SEPARATE DISCONNECT SWITCH AT THE CONTROLLER.	Plant / Irrig. Type AKc Pr Rate IE JAN FEB MAR APR MAY JUN JUL AUG SEP OCT NOV DEC Shrubs 0.40 0.64 0.90 2.5 3.3 4.7 6.6 7.1 9.2 9.3 8.6 7.9 5.5 3.4 2.4 Min./Day/Zone Drip Number of Zones: 6 15.1 19.8 28.2 39.9 42.3 55.4 55.5 51.7 47.6 32.9 20.4 14.1 Total Min./Day	
	20. CONTRACTOR SHALL VERIFY THE FIELD CONDITIONS AND INSTALL ADDITIONAL IN- LINE CHECK VALVES WHEREVER NECESSARY TO PREVENT LOW-HEAD DRAINAGE.	Trees 0.80 3.00 0.90 1.1 1.4 2.0 2.8 3.0 3.9 3.7 3.4 2.3 1.5 1.0 Min./Day/Zone Bubbler Number of Zones: 4 4.3 5.6 8.0 11.3 12.0 15.8 15.8 14.7 13.6 9.4 5.8 4.0 Total Min./Day	
	21. ALL TREES ARE TO BE WATERED BY A SEPARATE BUBBLER SYSTEM. SEE IRRIGATION DETAIL FOR BUBBLER INSTALLATION.	Shrubs 0.40 0.39 0.80 4.6 6.1 8.7 12.3 13.0 17.1 15.9 14.7 10.1 6.3 4.3 Min./Day/Zone MP Rotators Number of Zones: 9 41.7 54.8 78.2 110.4 117.2 153.5 153.7 143.3 131.9 91.2 56.5 39.1 Total Min./Day	
) MG	22. INSTALL X-OVER SLEEVES (CLASS 315 PVC UNLESS NOTED OTHERWISE) WHERE SHOWN ON THE PLANS, AT INTERSECTIONS, AND WHEREVER PIPE CROSSES UNDER PAVEMENTS. ALL SLEEVES SHALL EXTEND 6" INTO PLANTING AREAS AT BOTH ENDS.	Shrubs 0.40 0.60 0.80 3.0 4.0 5.6 8.0 8.5 11.1 11.1 10.3 9.5 6.6 4.1 2.8 Min./Day/Zone Rotors Number of Zones: 23 69.2 91.0 129.8 183.4 194.8 254.9 255.3 238.0 219.1 151.5 93.9 64.9 Total Min./Day	
ILE NAM	CONTRACTOR SHALL COORDINATE THE INSTALLATION OF THE SLEEVES PRIOR TO PAVING/PATH/ETC. BEING INSTALLED. NOT ALL SLEEVES MAY BE INDICATED ON PLANS.	Total Number of Zones: 42 130 171 244 345 366 480 480 448 412 285 177 122 Total Min./Day	
RD IRR	23. "BORE" UNDER EXISTING PAVING WHEREVER POSSIBLE. SAWCUT EXISTING PAVING WHERE NECESSARY AS APPROVED TO INSTALL PIPING/SLEEVE.		
OXFG	24. CONTRACTOR SHALL ADJUST EXACT LOCATIONS OF IRRIGATION PIPES AND TUBINGS TO AVOID CATCH BASINS AND OTHER SITE AMENITIES.	IRRIGATION PRESSURE CALCULATION 'A13' HIGHEST FLOW AT HIGHEST ELEVATION	
	25. VERIFY THE EXISTING GROUNDING SYSTEM. SEE SPECIAL PROVISIONS FOR ADDITIONAL INFORMATION.	STATION #: A13 STATIC PRESSURE: 85PSI FARTHEST SYSTEM/ MAX. GPM DEMAND: 36.1GPM HIGHEST FLOW SYSTEM	
IADO	26. ALL HEADS WITH CHECK VALVES AND PRESSURE REGULATION DEVICES IN POP-UP STEM SHALL BE CONNECTED THOUGH BOTTOM INLET AND NOT SIDE INLET.	L.F. SIZE TYPE DESCRIPTION GPM UNIT PSI LOSS 2" BRASS WATER METER 36.1 1.0 2" BRASS BACKFLOW/STRAINER 36.1 12	
CHECKE ERIC V	STEW SHALL BE CONNECTED THOUGH BOTTOM MILLT AND NOT SIDE MILLT.	2" BRASS MASTER VALVE 36.1 1.0	SWEENEY + associates IRRIGATION DESIGN AND CONSULTING
		1100' 2.5" CL. 315 MAIN LINE 36.1 4.3	38730 Sky Canyon Drive, Suite C Murrieta, Ca 92563 e: info@sweeneyassoc.comit: (951) 461-6830 w: www.sweeneyassoc.comif: (951) 461-6850
CURRY			LOS ANGELES DEPARTMENT OF PUBLIC WORKS
CHRIS		ELEVATION LOSS:10'TO 15' 2.2 PSI	FORD RETENTION BASIN
		RESIDUAL PRESSURE 10.1 PSI MULTIUS WEST TO STREET	SE ENHANCEMENT PROJECT
URRY			IRRIGATION LEGENDS
RAFTER CHRIS C		CALL 8-1-1 TOLL FREE 2 workings days before you dig REVISIONS DESCRIPTION PROJECT LANDSCAPE ARCHITECT DATE PROJECT LANDSCAPE ARCHITECT DATE	LS-3.0 CA EF21507000 WMD SHEET 14 OF 27
		THE VIOLET BY DESIGNATION OF THE PARTY OF TH	












IRRIGATION NOTES:

- SEE SHEET 13 FOR IRRIGATION LEGEND AND FOR IRRIGATION INSTALLATION NOTES.
- SEE SHEETS 19 AND 20 FOR IRRIGATION DETAILS.
- 3. WORK SHOWN ON THE IRRIGATION PLANS IS DIAGRAMMATIC. LOCATE NEW IRRIGATION LINES, VALVES AND EQUIPMENT IN PLANTING AREAS. AVOID LOCATING LINES WHERE MAJOR TREES ARE PROPOSED.
- 4. CONTRACTOR SHALL VERIFY THE EXISTING WATER PRESSURE AT THE PROPOSED POINT OF CONNECTION PRIOR TO INSTALLATION OF SYSTEM. CONTRACTOR SHALL TAKE A PHOTO OF THE STATIC WATER PRESSURE AT THE EXISITING BACKFLOW AND SUBMIT TO THE COUNTY
- AUTOMATIC IRRIGATION CONTROLLER 'A'. CONTROLLER TO BE WALL MOUNTED OUTSIDE OF ELECTRICAL ROOM.
- P.O.C. FOR THE WATER TO BE DOWNSTREAM OF THE WATER METER. AVAILABLE WATER PRESSURE IS 85 PSI. SEE IRRIGATION INSTALLATION NOTES FOR ADDITIONAL INFORMATION.

SWEENEY + associates
IRRIGATION DESIGN AND CONSULTING



38730 Sky Canyon Drive, Suite C Murrieta, Ca 92563 e: info@sweeneyassoc.comit: (951) 461-6830 w: www.sweeneyassoc.comif: (951) 461-6850



2 workings days before you dig

DESCRIPTION REVISIONS

GRAPHIC SCALE: 1"=20'


OXFORD RETENTION BASIN MULTIUSE ENHANCEMENT PROJECT


IRRIGATION PLAN

COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC WORKS

LS-3.5

PCA EF21507000 WMD SHEET 19 OF 27





GENERAL PLANTING NOTES:

- PLANT QUANTITIES IN LEGEND ARE FOR CONTRACTOR'S CONVENIENCE ONLY. OTHER THAN CONTRACT GROWN PLANT MATERIAL, CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL PLANTS SHOWN ON PLANTING PLANS.
- 2. ALL TREES ARE TO BE PLANTED MIN. 20' FROM EXISTING POWER POLES (WHERE APPLICABLE).
- CONTRACTOR SHALL PROVIDE 3" DEEP LAYERS OF MEDIUM TO FINE TEXTURED (3/4" TO 2") GROUND WOOD BY-PRODUCT OR SHREDDED BARK MULCH TO ALL NON-PAVED AREAS. COLOR OF MULCH SHALL BE DARK.
- PLANS ARE DIAGRAMMATIC. THE CONTRACTOR SHALL BRING TO THE ATTENTION OF THE ENGINEER ANY PERCEIVED DISCREPANCY BEFORE THE START OF CONSTRUCTION.
- SOIL SHALL BE REPLACED PER PLANTING POCKET. EXCAVATED EXISTING SOIL SHALL BE REMOVED FROM THE SITE AND DISPOSED OF PROPERLY. CONTRACTOR SHALL PROVIDE AND INSTALL IMPORTED TOPSOIL TO FILL IN EXCAVATED AREAS WHERE PLANTINGS ARE PROPOSED. IMPORTED TOPSOIL SHALL CONFORM TO SECTION L, LANDSCAPE OF SPECIAL PROVISIONS. AN AGRONOMICAL SOIL'S REPORT SHALL BE SUBMITTED PER 1.02-2 OF THE SAME SECTION, REVIEWED AND APPROVED BY THE ENGINEER PRIOR TO THE DELIVERY OF THE SOIL ON SITE.
- ANY SOIL PREPARATION AND PLANTING WITHIN THE DRIP LINE OF THE EXISTING TREES SHALL BE DONE BY HAND.

		PLANTING LEGEND				WATER	PLANTIN POCKET
ID	SYMBOL	BOTANICAL NAME / COMMON NAME	SIZE	QTY	SPACING/ REMARKS	M N N	DIA./ DEPTH
		TREES			7 12 17 11 11 10		-
		ADDUTUG 'MADINA' / CTDAMDEDDY TDEE	04" DOV	10	CTAND ADD		40" /76
		ARBUTUS 'MARINA' / STRAWBERRY TREE	24" BOX	16	STANDARD	L	48"/36
	(\cdot)	QUERCUS AGRIFOLIA / COAST LIVE OAK	24" BOX	13	STANDARD	L	48"/36
		UMBELLULARIA CALIFORNICA / CALIFORNIA LAUREL	24" BOX	3	STANDARD	L	48"/36
	3 * *	EXISTING TREES TO REMAIN					
		SHRUBS, VINES & GROUNDCOVERS					
ALT MIX		COASTAL SALT MARSH MIX: [SEE PLANT LEGEND NOTE (**)] (*PROVIDED BY DPW)					
		[15% BY AREA, 312 PLANTS PER 1,000 S.F.] SPERGULARIA MARINA / SAND MARSH SPURRY	4" POT	11,157	9" O.C.	NA	12"/24
		[30% BY AREA, 21 PLANTS PER 1,000 S.F.] DISTICHLIS SPICATA / SALTGRASS (**) [30% BY AREA 153 PLANTS PER 1,000 S.F.]	1 GAL.	779	48" O.C.	NA	24"/36
		[30% BY AREA, 153 PLANTS PER 1,000 S.F.] SALICORNIA VIRGINICA / COMMON PICKLEWEED (**) [15% BY AREA, 312 PLANTS PER 1,000 S.F.]	4" POT	5463	18" O.C.	NA	12"/24
	ンシンシ	FRANKENIA SALINA / ALKALI HEATH [10% BY AREA, 7 PLANTS PER 1,000 S.F.]	4" POT	11,157	9" O.C.	NA	12"/24
		JUNCUS ACUTUS LEOPOLDI / SOUTHWEST SPINY RUSH	1 GAL.	250	48" O.C.	M	24"/3
AGE MIX		COASTAL SAGE & BLUFF SCRUB MIX: (*PROVIDED BY DPW)					
		[15% BY AREA, 11 PLANTS PER 1,000 S.F.] ARTEMISIA CALIFORNICA / CALIFORNIA SAGEBRUSH	1 GAL.	987	48" O.C.	L	24"/36
		20% BY AREA, 14 PLANTS PER 1,000 S.F.] ENCELIA CALIFORNICA / CALIFORNIA ENCELIA [15% BY AREA, 44 PLANTS PER 1,000 S.F.]	1 GAL.	1256	48" O.C.	VL	24"/36
		ERIOGONUM PARVIFOLIUM / SEACLIFF BUCKWHEAT 20% BY AREA, 14 PLANTS PER 1,000 S.F.]	1 GAL.	3946	24" O.C.	VL	18"/36
		ERIOGONUM FASCICULATUM / CAL. BUCKWHEAT [15% BY AREA, 44 PLANTS PER 1,000 S.F.]	1 GAL.	1256	48" O.C.	VL	24"/36
		NASSELLA PULCHRA / PURPLE NEEDLEGRASS [15% BY AREA, 3 PLANTS PER 1,000 S.F.]	1 GAL.			VL	18"/36
PRAL		RHUS INTEGRIFOLIA / LEMONADE BERRY COASTAL PRAIRIE MIX: (*PROVIDED BY DPW)	5 GAL.	269	(96")8'O.C.	VL	36"/36
MIX	/	[35% BY AREA, 46 PLANTS PER 1,000 S.F.] ISOCOMA MENZIESII / COASTAL GOLDENBUSH	1 GAL.	193	36" O.C.	VL	24"/36
	、	[50% BY AREA, 145 PLANTS PER 1,000 S.F.] NASSELLA PULCHRA / PURPLE NEEDLE GRASS	1 GAL.	606	24" O.C.	VL	18"/36
	Y Y L X X L Y , Y ,	[15% BY AREA, 312 PLANTS PER 1,000 S.F.] SISYRINCHIUM BELLUM / BLUE EYED GRASS	1 GAL.	1303	9" O.C.	L	12"/24
CRN MIX		SCREENING MIX: [SEE PLANT LEGEND NOTE (***)] (*PROVIDED BY DPW)					
		[30% BY AREA, 6 PLANTS PER 1,000 S.F.] BACCHARIS SALICIFOLIA / MULEFAT [5% BY AREA, 4 PLANTS PER 1,000 S.F.]	5 GAL.	145	(96")8'O.C	М	36"/36
		ROSA CALIFORNICA / WILD ROSE [5% BY AREA, 4 PLANTS PER 1,000 S.F.]	5 GAL.	97	48"O.C	L	24"/36
		RUBUS URSINUS / CALIFORNIA BLACKBERRY [20% BY AREA, 4 PLANTS PER 1,000 S.F.]	5 GAL.		48"O.C		24"/36
		SAMBUCUS MEXICANA / BLUE ELDERBERRRY [30% BY AREA, 6 PLANTS PER 1,000 S.F.]	15 GAL.		(96")8'0.C		36"/36
		SALIX EXIGUA / NARROWLEAF WILLOW [10% BY AREA, 7 PLANTS PER 1,000 S.F.]	15 GAL.		(96")8'0.C		36"/36
		VITIS GIRDIANA / DESERT GRAPE (***)	5 GAL.	169	48"O.C.	L	24"/36

PLANTING LEGEND CONTINUED					WATER USE	PLANTING POCKET	
ID	SYMBOL	BOTANICAL NAME / COMMON NAME	SIZE	QTY	SPACING/ REMARKS		DIA./ DEPTH
SWAL MIX		GRASSY SWALE MIX: (*PROVIDED BY DPW)					
		[35% BY AREA, 24 PLANTS PER 1,000 S.F.] DISTICHLIS SPICATA / SALTGRASS	1 GAL.	101	48" O.C.	NA	24"/36"
		[35% BY AREA, 24 PLANTS PER 1,000 S.F.] JUNCUS ACUTUS / SPINY RUSH [30% BY AREA, 39 PLANTS PER 1,000 S.F.]	1 GAL.	101	48" O.C.	М	24"/36"
		CAREX BARBARAE / SANTA BARBARA SEDGE	1 GAL.	164	36" O.C.	М	24"/36"
		ORNAMENTAL MIX:					
ARC HOO	A	ARCTOSTAPHYLOS HOOKERI / MONTEREY MANZANITA	5 GAL.	36	4' O.C.	L	24"/36"
CEA EBB	©	CEANOTHUS 'EBBET'S FIELD' / DWARF WILD LILAC	5 GAL.	144	3' O.C.	L	24"/36'
LIM CAL		LIMONIUM CALIFORNICA / SEA LAVENDER	1 GAL.	220	3' O.C.	L	24"/36'
SAL SPA	S	SALVIA SPATHACEA / HUMMINGBIRD SAGE	1 GAL.	99	3' O.C.	L	24"/36'
COR MAR	©	COREOPSIS MARITIMA / SEA DAHLIA	1 GAL.	150	2' O.C.	L	18"/36'
VER LIL	⊕	VERBENA LILACINA "DE LA MINA" / CEDROS ISLAND VERBENA	1 GAL.	133	3' O.C.	L	24"/36'
ERI KAR	Θ	ERIGERON KARVINSKIANUS/ SANTA BARBARA DAISY	1 GAL.	50	3' O.C.	М	24"/36'
JUS BRA	6	JUSTICIA BRANDEGEANA / SHRIMP PLANT	1 GAL.	43	3' O.C.	М	24"/36'
FES CAL	Ф	FESTUCA CALIFORNICA / CALIFORNIA FESCUE	1 GAL.	315	18" O.C.	М	12"/24'
IRI DOU	0	IRIS DOUGLASIANA / DOUGLAS IRIS	1 GAL.	100	18" O.C.	М	12"/24'
HEU MAX	Θ	HEUCHERA MAXIMA / ISLAND ALUM ROOT	1 GAL.	54	3' O.C.	М	24"/36'
RHU INT		RHUS INTEGRIFOLIA / LEMONADE BERRY	5 GAL.	12	(96")8'O.C.	VL	36"/36
_		MULCH AROUND EXISTING PLANTS					


PLANT LEGEND NOTES:

(*PURCHASED AND PROVIDED BY DPW) - PLANTS LISTED UNDER "COASTAL SALT MARSH MIX, COASTAL SAGE & BLUFF SCRUB MIX, COASTAL PRAIRIE MIX, SCREENING MIX, AND GRASSY SWALE MIX," WILL BE PRE-ORDERED BY THE COUNTY UNDER SEPARATE CONTRACT. CONTRACTOR WILL BE RESPONSIBLE FOR OBTAINING PLANTS LISTED IN THE CATEGORIES "TREES" AND "ORNAMENTAL MIX"

(**) - ELEVATION FOR COASTAL SALT MARSH MIX AREA IS TO BE BETWEEN +O' MSL AND +3' MSL. SALICORNIA VIRGINICA / COMMON PICKLEWEED IS TO BE LIMITED TO THE MIDDLE ZONE (+1' MSL TO +2' MSL) WITHIN THE COASTAL SALT MARSH AREA. DISTICHLIS SPICATA / SALTGRASS IS TO BE LIMITED TO THE UPPER THIRD (+2' MSL TO +3' MSL) WITHIN THE COASTAL SALT MARSH AREA.

(***) - LIMIT VITIS GIRDIANA / DESERT GRAPE TO FENCE LINES IN THE SCREENING MIX AREAS. SUPPLY SUPPORT TIES AS NECESSARY.

PLANT CALLOUT KEY:



PLAN LS

DATE MK DESCRIPTION

REVISIONS

OXFORD RETENTION BASIN MULTI-USE ENHANCEMENT PROJECT

COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC WORKS


PLANTING LEGEND & NOTES


LS-4.0


FCC0001176 PCA EF21507000 PROJECT LANDSCAPE ARCHITECT


CALL 8-1-1 TOLL FREE 2 workings days before you dig


SHEET 22 OF 27











GENERAL NOTES:


- A. (10,000) = AVAILABLE 10 FAULT CURRENT OF 10,000 AMPS (RMS, SYM. AMPS).
- B. ALL WORK SHALL BE IN ACCORDANCE WITH THE 2011 COUNTY OF LOS ANGELES ELECTRICAL (2008 NEC), THE ELECTRICAL ORDINANCES OR CODES OF LOCAL AUTHORITY HAVING JURISDICTION.
- C. AGENCY SHALL OBTAIN ALL REQUIRED ELECTRICAL PERMITS. ARRANGE FOR ALL REQUIRED ELECTRICAL INSPECTIONS.
- D. WORK UNDER THIS CONTRACT SHALL INCLUDE, BUT NOT TO BE LIMITED TO, FURNISHING, INSTALLING AND CONNECTION OF ALL ELECTRICAL EQUIPMENT AND TESTING OF ALL SYSTEMS AND SUB-SYSTEMS WITHIN THE SCOPE OF WORK. BEFORE ACCEPTANCE OF THE WORK, THE CONTRACTOR SHALL DEMONSTRATE, IN THE PRESENCE OF THE ENGINEER, THAT ALL PORTIONS OF THE ELECTRICAL WORK ARE OPERATING PROPERLY PER MANUFACTURER'S SPECIFICATION.
- E. PROJECT SITE SHALL BE KEPT BROOM CLEAN AFTER COMPLETION OF WORK. ALL TRASH/DEBRIS GENERATED DURING CONSTRUCTION SHALL BE THE PROPERTY OF THE CONTRACTOR AND DISPOSED BY THE CONTRACTOR.
- F. ALL ITEMS ARE NEW.
- G. CONDUCTORS: ALL SHALL BE COPPER, RATED 600V, INSULATION TYPE THWN.
- H. CONDUITS: EXPOSED OUTDOOR CONDUITS SHALL BE RIGID GALVANIZED STEEL (RGS), ALL EXTERIOR UNDERGROUND CONDUITS SHALL PVC40 (STRAIGHT RUNS) & PVC80 (SWEEPS), SEE ELECTRICAL SITE PLAN FOR CONDUIT SIZE. ALL CONDUIT RUNS SHALL HAVE A GREEN INSULATED EQUIPMENT GROUNDING CONDUCTOR SIZED PER NEC.
- I. ALL ELECTRICAL MATERIALS SHALL BE LISTED BY U.L.


PUMP CONTROL HOUSE


NO SCALE

LEGEND:

- BOLLARD LIGHT FIXTURE, 8" SQUARE BY 43" HIGH VANDAL RESISTANT CONCRETE, NATURAL GRAY, 15—LED TYPE 3 5100K, 180° COVERAGE, 120V—277V. ARROW INDICATES DIRECTION OF ILLUMINATION. NUMBER—DENOTES CIRCUIT NUMBER. LIGHT FIXTURE SHALL BE OR COUNTY APPROVED EQUAL TO KIM LIGHTING CAT. #VSB1C—15L (IES TYPE 3)—5100K—UV.
- IN-WALL STEP LIGHT FIXTURE, 10" SQUARE, LIGHT GREY, 9-LED BRIGHT WHITE 5100K, 120V-277VAC. NUMBER-DENOTES CIRCUIT NUMBER. LIGHT FIXTURE SHALL BE OR COUNTY APPROVED EQUAL TO ARCHITECTURAL AREA LIGHTING CAT. #ASL10SQLS-9LEDBW-LGY-BSA.
- ——— UNDERGROUND BRANCH CIRCUIT, SEE SITE PLAN FOR CONDUIT AND WIRES SIZES.
- CALL OUT NOTE NUMBER 1.







ONE-LINE DIAGRAM
TIDE GATE CONTROL HOUSE

NO SCALE

DATE MK DESCRIPTION

E15357

Exp. date: 06-30-13

DATE MK DESCRIPTION

REVISIONS

OXFORD RETENTION BASIN

COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC WORKS

MULTI-USE ENHANCEMENT PROJECT

ELECTRICAL LEGEND, GENERAL NOTES, DETAILS, ONE—LINE DIAGRAM

FCC0001176 | PCA EF21507000

SHEET E-0.1

1. WORK INLCUDED:

PROVIDE ALL LABOR, MATERIALS, APPLIANCES, TOOLS, EQUIPMENT, FACILITIES, TRANSPORTATION, AND SERVICES NECESSARY FOR AND INCIDENTAL TO PERFORMING ALL OPERATIONS IN CONNECTION WITH FURNISHING, INSTALLATION, AND MAKING FULLY OPERATIONAL THE WORK OF THIS DIVISION, COMPLETE, AND AS SHOWN AND/OR SPECIFIED HEREIN.

- A. EXCEPT SUCH MATERIAL OR EQUIPMENT SPECIFICALLY INDICATED AS PROVIDED BY THE OWNER, OR BY OTHERS.
- B. PRIOR TO COMMENCING THE WORK, CONTRACTOR SHALL INSPECT THE SITE AND BY SUBMITTING A BID FOR THE WORK, SHALL BE DEEMED TO HAVE VERIFIED ALL EXISTING CONDITIONS AND ACCEPTS SAME AS TRUE AND COMPLETE.

C. RELATED SECTIONS AND ASSOCIATED WORK:

- 1. DIVISION 1 AND THE GENERAL CONDITIONS OF THE CONTRACT APPLY TO ALL WORK HEREIN SPECIFIED. ADDITIONALLY, THIS SPECIFICATION SUPPLEMENTS THE APPLICABLE REQUIREMENTS OF OTHER DIVISIONS.
- 2. EQUIPMENT, DEVICES AND WIRING FURNISHED UNDER DIVISION 15 AND INDICATED FOR INSTALLATION UNDER THIS DIVISION SHALL BE INSTALLED IN ACCORDANCE WITH DIVISION 15 AND ASSOCIATED DRAWINGS.
- 3. CUTTING, DRILLING, AND PATCHING SHALL BE DONE IN ACCORDANCE WITH THE APPLICABLE SECTIONS OF THE SPECIFICATIONS.

2. SUBMITTALS:

SUBMIT WRITTEN INFORMATION TO THE OWNER FOR APPROVAL, AS FOLLOWS:

- A. PRODUCT DATA AND SHOP DRAWINGS: THREE COPIES WITHIN FIVE (5) DAYS OF THE AWARD OF CONTRACT. EQUIPMENT AND MATERIALS FOR WHICH SUBMITTALS ARE REQUIRED SHALL INCLUDE: WIRING DEVICES; SWITCHBOARDS; DISCONNECT SWITCHES; TRANSFORMERS; PANELBOARDS; MOTOR CONTROLLERS; LIGHT FIXTURES AND LIGHTING SYSTEM—ASSOCIATED CONTROL SYSTEM COMPONENTS, POLES AND MOUNTING BASES. (SUBMITTALS FOR REINFORCED CONCRETE BASES FOR LIGHTING POLES SHALL INCLUDE FOUNDATION DESIGN/INSTALLATION DRAWINGS SIGNED BY A STRUCTURAL ENGINEER CURRENTLY REGISTERED IN THE STATE OF CALIFORNIA)
- 1. SUBSTITUTIONS: MANUFACTURER AND CATALOG NUMBERS INDICATED ARE FOR THE PURPOSE OF ESTABLISHING STANDARDS OF QUALITY, ALLOWABLE SIZE OF COMPONENTS, AND TYPE OF MATERIALS TO BE USED. PRODUCTS BY OTHER MANUFACTURERS WILL BE CONSIDERED IF THE SUBMITTAL ASSOCIATED WITH THAT ITEM IS CLEARLY MARKED "THIS ITEM IS A SUBSTITUTION", AND IT COMPLIES WITH THE FOLLOWING: (1) QUALITY AND CAPACITY ARE EQUAL TO OR BETTER THAN THE SPECIFIED ITEM, AND (2) COMPONENTS FIT IN THE ALLOWED SPACES AND ARE SIMILAR IN APPEARANCE. NO SUBSTITUTION ITEMS MAY BE FURNISHED OR INSTALLED WITHOUT WRITTEN APPROVAL OF THE OWNER.
- B. OPERATIONS AND MAINTENANCE MANUALS: THREE COPIES OF OPERATING AND MAINTENANCE DATA FOR ALL ELECTRICAL EQUIPMENT, BOUND IN A HARDCOVER THREE—RING PLASTIC BINDER WITH A TABLE OF CONTENTS.
- C. RECORD DRAWINGS: DURING THE WORK, MAINTAIN A SET OF AS—BUILT DRAWINGS AT THE SITE BY NOTING ON THEM IN WRITING (IN CLEAR, NEAT AND THOROUGH MANNER) ALL CHANGES TO THE CONTRACT. ANNOTATIONS SHALL BE CURRENT WITH ALL WORK PERFORMED. SUBMIT THESE RECORD DRAWINGS UPON COMPLETION OF THE WORK.

3. COORDINATION:

PROVIDE NECESSARY COORDINATION WITH SERVING UTILITY COMPANIES TO ESTABLISH SERVICE ENTRANCE FACILITIES, AND TO MEET OTHER REQUIREMENTS FOR A COMPLETE AND OPERABLE INSTALLATION. VERIFY SIZE AND ORIENTATION OF EQUIPMENT TO BE INSTALLED IN INTERIOR SPACES WITH THE MANUFACTURER OF THAT EQUIPMENT TO ENSURE ADEQUATE WORKING CLEARANCES AND VENTILATION. COORDINATE THE WORK OF OTHER TRADES, VERIFY REQUIRED WORKING CLEARANCES, SLEEVES, SUPORTS, DOOR. SWINGS, AND OTHER ITEMS AFFECTING THE WORK OF THIS SECTION. VERIFY THE METHODS OF INSTALLING AND CONNECTING EQUIPMENT, OUTLETS, AND OTHER ITEMS.

4. QUALITY ASSURANCE:

ALL MATERIALS AND THE MANNER IN WHICH THEY ARE APPLIED AND INSTALLED SHALL BE IN COMPLIANCE WITH THE LATEST RULES AND REGULATIONS OF THE CALIFORNIA CODE OF REGULATIONS TITLE 24, PART 3 "CALIFORNIA ELECTRICAL CODE"; THE NATIONAL ELECTRICAL CODE; AND OTHER APPLICABLE STATE AND LOCAL LAWS AND REGULATIONS.

5. PERMITS, FEES, AND INSPECTIONS:

OBTAIN AND PAY FOR PERMITS AND LICENSES REQUIRED FOR THE WORK. OBTAIN PERMITS PRIOR TO COMENCING ANY WORK. ARRANGE FOR AND SCHEDULE REQUIRED INSPECTIONS. PAY UTILITY FEES AND CHARGES REQUIRED TO ESTABLISH PERMANENT SERVICE, AND ANY OTHER UTILITY FEES.

6. PROTECTION AND CLEANING:

ALL PARTS OF EQUIPMENT AND MATERIALS SHALL BE THOROUGHLY CLEANED. PROTECT ALL WORK, MATERIALS AND EQUIPMENT FROM DAMAGE FROM ANY CAUSE AND PROVIDE ADEQUATE AND PROPER STORAGE FACILITIES DURING THE PROGRESS OF THE WORK. PROVIDE FOR THE SAFETY AND GOOD CONDITION OF ALL THE WORK UNTIL FINAL ACCEPTANCE BY THE OWNER. REPLACE ALL DAMAGED OR DEFECTIVE WORK, MATERIALS AND EQUIPMENT PRIOR TO REQUESTING FINAL ACCEPTANCE. PROVIDE AND MAINTAIN SUITABLE BARRIERS, WARNING SIGNS, LIGHTS, ETC., WHERE REQUIRED FOR PROTECTION OF THE PUBLIC AND OCCUPANTS ABOUT THE SITE. AT THE CONCLUSION OF EACH WORKDAY, THE PREMISES SHALL BE LEFT FREE FROM DEBRIS INCIDENTAL TO THE WORKDAY, AND IN A CONDITION ACCEPTABLE TO THE OWNER OR

7. GUARANTEES:

PROVIDE A ONE YEAR MINIMUM WRITTEN GUARANTEE (IN A MANNER ACCEPTABLE TO THE OWNER) AGAINST DEFECTS IN WORKMANSHIP OR MATERIALS.

1. GENERAL:

- A. <u>Grounding and Bonding:</u> Grounding and Bonding Shall be provided in compliance with all applicable codes and regulations, both of the state of California and the authorities having jurisdiction.
- B. <u>ELECTRICAL IDENTIFICATION:</u> PROVIDE NAMEPLATES FOR SWITCHBOARDS, PANELBOARDS, DISCONNECT SWITCHES, CONTACTORS/RELAYS, TERMINAL CABINETS/BACKBOARDS, MOTOR CONTROLLERS, INDIVIDUALLY—MOUNTED CIRCUIT BREAKERS, PULL BOXES, CONTROL PANELS, TIME CLOCKS, AND FOR ANY OTHER CONTROL DEVICE OR MAJOR ITEM OF ELECTRICAL EQUIPMENT.
- 1. NAMEPLATES SHALL BE BLACK-ON-WHITE (NORMAL POWER) OR RED-ON-WHITE (EMERGENCY POWER) LAMINATED PLASTIC, ATTACHED WITH MACHINE SCREWS. LETTERING SHALL BE 1/4" HIGH MINIMUM, CORRESPONDING TO THE DESIGNATION (OR ADDITIONAL INFORMATION) SHOWN

C. PRELIMINARY OPERATION AND TESTING:

- 1. ALL WIRING AND CONNECTIONS SHALL BE TESTED FOR CONTINUITY (OPENS AND SHORTS) AND PROPER GROUNDING IN ACCORDANCE WITH THE REQUIREMENTS OF THE NEC.
- 2. ALL MOTOR-DRIVEN EQUIPMENT SHALL BE EXAMINED FOR COMPLETION OF ALL CONNECTIONS, AND TESTED FOR CORRECT ROTATION.

2. RACEWAY AND BOXES:

THE APPLICATION AND INSTALLATION OF RACEWAY AND BOXES SHALL BE IN COMPLIANCE WITH NEC REQUIREMENTS. WHERE THE SIZE OF RACEWAY OR BOXES ARE NOT INDICATED, THE CONTRACTOR SHALL SIZE THESE ITEMS AS REQUIRED FOR THE INSTALLATION. MINIMUM CONDUIT SIZE SHALL BE 3/4 INCHES. PROVIDE GALVANIZED PRESSED STEEL OUTLET BOXES OF PROPER SIZE AND TYPE AS REQUIRED BY THE BUILDING CONDITIONS FOR ALL INTERIOR OUTLETS FOR RECEPTACLES, SWITCHES, LIGHTING, VOICE/DATA COMMUNICATIONS SYSTEMS JACKS, AND OTHER EQUIPMENT/DEVICES WHICH REQUIRE POWER SUPPLY OR CONTROL/SIGNAL CABLING CONNECTIONS. OUTLETS FOR WALL—MOUNTED SWITCHES SHALL BE INSTALLED ADJACENT TO THE TRIM ON THE STRIKING SIDE OF THE DOOR, REGARDLESS OF THE LOCATION SHOWN — THEREFORE, CONFIRM ALL DOOR SWINGS PRIOR TO ROUGH—IN OF OUTLETS AND RACEWAY. ALL RACEWAY INSTALLED AT THIS TIME BUT LEFT EMPTY FOR FUTURE WORK (THAT IS, SHOWN AS CONDUIT ONLY, OR C.O.) SHALL BE PROVIDED WITH A 1/8" DIAMETER POLYPROPYLENE PULL ROPE FROM END—TO—END.

- A. WIRING METHOD SHALL BE AS FOLLOWS, EXCEPT AS OTHERWISE INDICATED
- 1. EXTERIOR, EXPOSED: RIGID GALVANIZED STEEL. FOR CONNECTION TO VIBRATING EQUIPMENT, USE LIQUIDTIGHT FLEXIBLE METAL CONDUIT.
- 2. EXTERIOR, CONCEALED: RIGID GALVANIZED STEEL. FOR CONDUIT IN SLAB OR UNDERGRADE, USE PVC SCHEDULE 40 (PROVIDE CONCRETE ENCASEMENT AS INDICATED)
- 3. INTERIOR, EXPOSED: RIGID GALVANIZED STEEL; OR ELECTRICAL METALLIC TUBING (EMT) AS ALLOWED BY THE NEC. FOR CONNECTION TO VIBRATING EQUIPMENT (INCLUDING MOTOR—DRIVEN EQUIPMENT AND TRANSFORMERS), USE LIQUIDTIGHT FLEXIBLE METAL CONDUIT, 18 INCHES MAXIMUM LENGTH. FOR CONNECTION TO LIGHTING FIXTURES ABOVE SUSPENDED ACOUSTICAL OR METAL CEILINGS, USE HEAVYWALL FLEXIBLE METAL CONDUIT, 72 INCHES MAXIMUM LENGTH.
- 4. INTERIOR, CONCEALED: EMT. FOR CONDUIT IN SLAB OR UNDER SLAB ON GRADE, USE PVC SCHEDULE 40 (PROVIDE CONCRETE ENCAEMENT AS

B. RACEWAY TYPES:

1. METALLIC CONDUIT:

- a. RIGID GALVANIZED STEEL (RGS): ANSI C80.1; ANSI/NEMA FB 1, UL 6/514B. THREADED STEEL TYPE, INSIDE AND OUTSIDE SURFACES ZINC-COATED BY HOT-DIP PROCESS.
- b. ELECTRICAL METALLIC TUBING (EMT): ANSI C80.3; UL 514B/797. WELDED ELECTRO—GALVANIZED STEEL TUBING. COUPLINGS AND CONNECTORS SHALL BE COMPRESSED TYPE.
- NONMETALLIC CONDUIT: NEMA TC-2/TC 3; UL 514B/651. PVC SCHEDULE 40, HEAVY-WALL, HIGH-IMPACT RIGID, RATED AND LABELED FOR USE WITH 90 DEGREE C-RATED CONDUCTORS.
- 3. FLEXIBLE CONDUIT: UL 1. HOT-DIP GALVANIZED STEEL INTERLOCKING, SINGLE-STRIP TYPE, MINIMUM INTERMEDIATE GRADE.
- 4. LIQUIDTIGHT FLEXIBLE METAL CONDUIT: ANSI/NEMA FB 1; UL 360. HOT-DIP GALVANIZED STEEL STRIP CORE WITH EXTRUDED LIQUIDTIGHT POLYVINYL JACKET.

C. RACEWAY INSTALLATION:

- 1. ALL EXPOSED CONDUIT SHALL BE RUN PARALLEL TO, OR AT RIGHT ANGLES TO, BUILDING WALLS OR STRUCTURAL MEMBERS.
- 2. SECURELY AND RIGIDLY SUPPORT ALL RACEWAY FROM THE BUILDING STRUCTURE. SECURE BY MEANS OF APPROVED PIPE CLAMPS OR STRAPS. PROVIDE SUPPORTS AT INTERVALS NOT EXCEEDING 10 FEET, AND WITHIN 3 FEET OF TERMINATIONS AND CHANGES IN DIRECTION.
- a. INDIVIDUAL SUSPENDED RACEWAYS ABOVE CEILINGS SHALL BE SUPPORTED BY MEANS OF HANGER RODS AND PIPE CLAMPS. MULTIPLE SUSPENDED RACEWAYS SHALL BE SUPPORTED BY MEANS OF TRAPEZE TYPE HANGERS ("C" CHANNELS OR "UNISTRUT") AND PIPE CLAMPS.
- b. INDIVIDUAL RACEWAY PLACED AGAINST CONCRETE, MASONRY OR BRICK WALLS OR SLABS SHALL BE SECURED WITH PIPE CLAMPS AND EXPANSION SHIELDS. ATTACHMENT TO DRYWALL OR PLASTER CONSTRUCTION SHALL BE BY MEANS OF PIPE CLAMPS AND SCREWS FASTENED TO STUDS OR OTHER STRUCTURAL MEMBERS. PROVIDE "C" CHANNEL SUPPORTS FOR ALL MULTIPLE RACEWAY RUNS SECURED TO WALLS OR SLABS.
- 3. CONDUIT RISERS LEAVING A CONCRETE SLAB SHALL BE RIGID GALVANIZED STEEL CONDUIT.
- D. OUTLET BOXES: NEMA OS 1; UL 50/514A/514B. ONE PIECE GALVANIZED STEEL KNOCKOUT TYPE, WITH CONDUIT ENTRANCES SIZED TO MATCH. PROVIDE BOXES OF THE PROPER CODE SIZE FOR THE NUMBER OF WIRES OR CONDUITS PASSING THROUGH OR TERMINATING THEREIN, WITH MINIMUM SIZE 4 INCHES SQUARE BY 2-1/8 UNCHES DEEP. FOR EXTERIOR LOCATIONS, AND WHERE INDICATED (WEATHERPROOF) USE CAST FERROUS FS TYPE WITH THREADED

- E. PULL BOXES AND JUNCTION BOXES FOR INTERIOR OR EXTERIOR ABOVE—GRADE LOCATIONS: ASTM 123/167; NEMA 250/ICS 6/OS 1; UL 50/514A/514B. SHEET STEEL, WITH BOLT—ON COVERS, AS FOLLOWS:
- 1. EXTERIOR OR WET LOCATIONS, AND WHERE INDICATED (WEATHERPROOF): HOT-DIP GALVANIZED AFTER CONSTRUCTION, WITH TWO COATS OF RUST-RESISTANT PAINT (GRAY COLOR). COVERS SHALL BE EQUIPPED WITH NEOPRENE GASKETS, AND SHALL BE INSTALLED WITH STAINLESS STEEL SCREWS. TO ENSURE WEATHERTIGHTNESS, SEAL CONDUIT ENTRANCES WITH SILICONE SEALANT.
- 2. INTERIOR DRY LOCATIONS: FINISH BOX SURFACES WITH PRIMER, AND PRIMER SEALER.
- F. PULL BOXES AND JUNCTION BOXES FOR EXTERIOR AT—GRADE OR BELOW—GRADE LOCATIONS: NEMA 250/ICS 6; UL 50/514A/514B. PRECAST CONCRETE, WITH CAST IRON COVER LABELED "ELECTRIC" OR "COMMUNICATIONS" AS APPLICABLE, EXCEPT AS OTHERWISE SHOWN, BY QUICKEST OR BROOKS PRODUCTS. INSTALL ON 6 INCH BED OF PEA GRAVEL.
- 1. NONMETALLIC BOXES, AT LOCATIONS SHOWN: NEMA OS 2; UL 514C. CAST PVC, WITH GASKETED BOLT—ON COVER USING STAINLESS STEEL SCREWS.
- G. CABINETS: CABINETS FOR PANELBOARDS, WIRING TERMINATIONS/MANAGEMENT, AND CONTROL EQUIPMENT SHALL BE FLUSH OR SURFACE MOUNTED AS SHOWN. CONSTRUCTION SHALL BE CODE—GAUGE ZINC—COATED SHEET STEEL BEARING THE UL LABEL. CABINET DOORS SHALL HAVE FLUSH CATCHES AND PIN TUMBLER LOCKS. WIRING GUTTERS OR SPACES SHALL BE PROVIDED AT TOP AND BOTTOM (MINIMUM DIMENSION 6 INCHES), AND ALONG THE SIDES (MINIMUM DIMENSION 4 INCHES). PROVIDE TERMINAL AND CONTROL CABINETS MADE BY THE MANUFACTURER OF THE PANELBOARDS, AND WITH THE SAME KEYING AND FINISH AS THE PANELBOARDS.

3. WIRE AND CABLE:

NEMA/ICEA WC-5; UL 83. CONDUCTOR SIZE AS SHOWN. CONDUCTOR SHALL BE SOFT-DRAWN COPPER, MINIMUM 98% CONDUCTIVITY. MINIMUM INSULATION RATING SHALL BE 600 V, TYPE THHN/THWN 75 DEGREES C RATING, OR TYPE XHHW 90 DEGREES C RATING. MINIMUM SIZE SHALL BE NO. 12 AWG. ALL WIRE NO. 8 AWG AND LARGER SHAL BE STRANDED.

- A. PROVIDE WIRE AND CABLE MANUFACTURED WITHIN ONE YEAR OF DATE OF DELIVERY TO THE JOBSITE. DELIVER WIRE AND CABLE TO SITE IN THEIR ORIGINAL UNBROKEN PACKAGES, OR ON THEIR ORIGINAL CABLE REELS. PACKAGES AND CABLE REELS SHALL BE MARKED AND TAGGED PLAINLY WITH UL LABEL, AWG OR CIRCULAR MIL SIZE, VOLTAGE RATING, INSULATION TYPE, CONDUCTOR TYPE AND TYPE OF STRANDING, MANUFACTURER'S NAME, TRADE NAME, AND MONTH AND DATE OF MANUFACTURE.
- B. USE ONLY PLATED COPPER ALLOY CONNECTORS OR LUGS, ALUMINUM CONNECTORS OR LUGS ARE NOT ACCEPTABLE. THE FOLLOWING CONNECTORS ARE APPROVED FOR COPPER CONDUCTORS:
- 1. WIRE NO. 10 AND SMALLER: 3M "SCOTCHLOK" OR IDEAL "SUPERNUT"
- 2. WIRE NO. 8 OR LARGER: SOLDERLESS CONNECTORS BY OZ GEDNEY, OR THE EQUIVALENT BY BUCHANAN, KEARNEY, OR THOMAS & BETTS.
- C. TAPE CONNECTIONS MADE WITH NON—INSULATED TYPE CONNECTORS WITH RUBBER TAPE, MINIMUM 150 PERCENT THE THICKNESS OF THE CONDUCTOR INSULATION, THEN COVERED WITH SCOTCH NO. 33 TAPE, OR EQUAL.
- D. COLOR CODE ALL WIRE WITH INSULATION/JACKET (FACTORY—APPLIED) COLOR FOR PHASE IDENTIFICATION (CONTINUOUS FOR CIRCUIT FROM OUTLET—TO—OUTLET, PULL BOX, OR CABINET) AS FOLLOWS:

DUACE	120/240V	208Y/120V	400V /07
<u>PHASE</u>			480Y/27
Α	BLACK	BLACK	BROWN
В	RED	RED	ORANGE
С	BLUE	BLUE	YELLOW
NEUTRAL	WHITE	WHITE	WHITE
GROUND	GREEN	GREEN	GREEN

4. WIRNG DEVICES:

NEMA WD 1, WD 6; UL 20, UL 486A. ALL WIRING DEVICES SHALL BE SPECIFICATION GRADE. COLORS SHALL BE AS SELECTED BY OWNER. TYPES SHALL BE AS FOLLOWS, EXCEPT AS OTHERWISE INDICATED:

- A. RECEPTACLES: DUPLEX, THREE-WIRE GROUNDING TYPE, RATED 20A AT 125V, NEMA CONFIGURATION 5-20R. PROVIDE GFI (SELF-CONTAINED) TYPE AT LOCATIONS SHOWN. FOR EXTERIOR LOCATIONS, PROVIDE WITH WEATHERPROOF BOX, AND ALUMINUM GASKETED SPRING-SHUT COVER. HUBBEL 53XX-SERIES, OR EQUAL FROM PASS & SEYMOUR OR LEVITON.
- B. SWITCHES: TOGGLE TYPE, NUMBER OF POLES AS SHOWN, QUIET TYPE, RATED 20A AT 120/277V. HUBBELL HBL 12XX—SERIES, OR EQUAL FROM PASS & SEYMOUR OR LEVITON.
- 1. INCANDESCENT DIMMER TYPE, AT LOCATIONS SHOWN: MODULAR SOLID—STATE TYPE, RATING AND NUMBER OF SWITCH POLES AS SHOWN, WITH CONTINUOUSLY—ADJUSTABLE ROTARY KNOB OR TOGGLE, ANODIZED ALUMINUM FACE, WITH SOFT—TAP OR OTHER QUIET ON—OFF SWITCH. HUBBELL AR—SERIES, OR EQUAL BY LEVITON.
- C. PLATES: WALL PLATES SHALL BE PROVIDED FOR EVERY SWITCH, RECEPTACLE, OUTLET AND JUNCTION BOX, TELEPHONE JACK, ETC. PROVIDE PLATES WHICH MATE AND MATCH WITH THE WIRING DEVICE(S) TO WHICH THEY ARE ATTACHED. EXCEPT AS OTHERWISE SHOWN, WALL PLATES FOR INTERIOR AREAS (EXCEPT FOR FOOD—PREPARARTION AREAS) SHALL BE SMOOTH HIGH—IMPACT RESISTANT PLASTIC TO MATCH ADJACENT SURFACES; AND WALL PLATES FOR FOOD PREPARARTION AREAS SHALL BE STAINLESS STEEL.

5. SWITCHBOARDS (SEE SINGLE LINE DIAGRAM):

NEMA PB 2; UL 891. RATED AS SHOWN. COPPER BUS. SQUARE-D, OR EQUAL BY GE OR CUTLER-HAMMER.

6. DISCONNECT SWITCHES:

NEMA KS 1, UL 98, UL 198C AND 198E. RATED AS SHOWN, HEAVY DUTY TYPE, EXTERNALLY—OPERATED, QUICK—MAKE QUICK—BREAK TYPE, THREE POLE EXCEPT AS OTHERWISE SHOWN. FOR FUSIBLE TYPE, PROVIDE DUAL—ELEMENT TIME—DELAY CLASS RK—1 CURRENT LIMITING FUSES. FOR EXTERIROR LOCATIONS, AND WHERE INDICATED, PROVIDE NEMA 3R ENCLOSURES. SQUARE—D, OR EQUAL BY GE OR CUTLER—HAMMER

7. TRANSFORMERS:

NEMA ST 20, UL 1561. DRY-TYPE GENERAL PURPOSE, 150 DEGREES C RISE AT FULL LOAD WITH 220 DEGREES C INSULATION SYSTEM. PROVIDE NEMA 3R ENCLOSURE WITH RAIN SHIELD FOR EXTERIOR APPLICATION. SQUARE-D, OR EQUAL BY GE OR CUTLER-HAMMER.

8. PANELBOARDS (SEE SINGLE LINE DIAGRAM AND PANEL SCHEDULE):

NEMA PB 1, PB 1.1, AND AB 1; UL 67. PROVIDE AS FOLLOWS, EXCEPT AS OTHERWISE INDICATED: COPPER BUS, WITH FULLY—RATED NEUTRAL; BOLT—ON MOLDED CASE CIRCUIT BREAKERS; NEMA 3R ENCLOSURE FOR OUTDOOR APPLICATION; WITH TYPEWRITTEN BRANCH CIRCUIT DIRECTORY. ALL MULTIPLE POLE CIRCUIT BREAKERS SHALL BE EQUIPPED WITH A COMMON TRIP HANDLE. SQUARE—D, OR EQUAL BY GE OR SIEMENS.

9. MOTOR CONTROLLERS:

NEMA ICS 2/ICS 6/250/AB 1/FU 1/KS 1; UL 98/198C/198E/489/508. PROVIDE MANUAL MOTOR CONTROLLERS FOR SINGLE-PHASE MOTORS RATED BELOW 2 HP, AND COMBINATION MOTOR CONTROLLERS AS SHOWN.

- A. MANUAL MOTOR CONTROLLER: MANUAL MOTOR STARTING SWITCH WITH INTEGRAL THERMAL TYPE OVERLOAD PROTECTION, TOGGLE LEVER TYPE, ALLEN-BRADLEY BULLETIN 609, OR EQUAL BY SQUARE-D, GE OR CUTLER-HAMMER.
- B. COMBINATION MOTOR CONTROLLERS: ENCLOSED COMBINATION STARTER, FUSIBLE DISCONNECT SWITCH TYPE, ALLEN-BRADLEY BULLETIN 512, OR EQUAL BY SQUARE-D. GE OR CUTLER-HAMMER.

10. LIGHTING (SEE LEGEND ON SHEET E-0.1):

PROVIDE ALL LIGHTING EQUIPMENT AND SYSTEMS SHOWN. ALL LIGHTING FIXTURES SHALL BE PROVIDED WITH LAMPS.

- A. TIME SWITCHES: PROVIDE WITH THE FOLLOWING RATINGS AND FEATURES, AS A MINIMUM: (1) NUMBER OF POLE: AS SHOWN, PLUS AT LEAST ONE SPARE; (2) 24 HOUR DIAL, WITH 3 HOUR MINIMUM SETTING; (3) MOTOR AND CONTACT VOLTAGES AS REQUIRED; (4) CONTACTS: SINGLE THROW. CONTACT RATING: 1HP AT 120VAC AND 40A AT 277VAC, EXCEPT CONTACTS MAY BE RATED A MINIMUM OF 10A IF RELAYS OR CONTACTORS ARE CONTROLLED; (5) POWER RESERVE FEATURE: 8 HOUR SPRING-DRIVEN AUTO REWIND RESERVE POWER. PARAGON, TORK, SANGAMO, OR INTERMATIC.
- B. PHOTOELECTRIC CONTROLLERS: RATED FOR CONNECTED LOAD, 20A MINIMUM. PARAGON, TORK, SANGAMO, OR EQUAL.
- C. LIGHTING CONTACTORS AND RELAYS: PROVIDE MINIMUM RATING AND NUMBER OF POLES AS SHOWN (IN ADDITION, WHERE INDIVIDUAL BRANCH CIRCUITS ARE CONTROLLED, PROVIDE ONE SPARE POLE). SQUARE—D, OR EQUAL BY GE OR CUTLER—HAMMER.

DATE MK DESCRIPTION

PROFESSIONALIA

ENDE LA

ENDE LA

EXP. date: 06-30-13

INTERIOR OF CALFORNIA

INTERIOR OF CAL

PROJECT ENGINEER

REVISIONS

COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC WORKS


OXFORD RETENTION BASIN
MULTI-USE ENHANCEMENT PROJECT


SPECIFICATIONS

SHEET E-0.2

FCC0001176 PCA EF21507000

2 **OF** 7







NOTE: HOMERUN THE 120V-20A CIRCUIT TO THE FOLLOWING PANEL BOARDS FOR EACH LIGHTING CONTROL PANEL.


A. CONTROL PANEL LOCATED AT THE TIDE: PANEL BOARD "L" CIRCUIT #10.
B. CONTROL PANEL LOCATED AT PUMP HOUSE: PANEL BOARD "A" CIRCUIT #4.


TYPICAL EXTERIOR LTG.


CONTROL DIAGRAM















SPECIFIC NOTES:

- 1" PVC SCHD40 4#8 & 1#8 E.G.C., 18" BELOW FINISH GRADE.
- (E) 15KVA MINI POWER CENTER 480-120/240V,1φ,3W WITH PANEL BOARD "A"
- \bigcirc (E) 200A-480Y/277VAC-3 ϕ -4W SYSTEM IN 6"x6"x4' WIRE GUTTER.
- (N) PATHWAY LIGHTING CONTROL PANEL. MOUNTED +46" ABOVE FINISH GRADE
- ⑤ (N) PANEL BOARD "P1".



COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC WORKS

OXFORD RETENTION BASIN MULTI-USE ENHANCEMENT PROJECT


ELECTRICAL SITE PLAN

SHEET E-4.0

6 6 ·

e e

7 **OF** 7



PROJECT SITE Thomas Bros. Pgs. 672 A6 671 J6

<u>UTILITIES</u>

LOCATION MAP

WATER. CITY OF LOS ANGELES DEPT OF WATER & POWER GAS.... THE GAS CO. **ELECTRIC** SO CALIF EDISON TELEPHONE SEWER.. · CITY OF LOS ANGELES BUREAU


OF SANITATION

REFERENCES PROJECT NO. 3872, UNIT 1 DWG. NO.470-3872-D3.1-13 PROJECT NO. 3872, UNIT 1, AUTOMATIC FLAPGATES DWG.NO.470-3872-D8.1-3 PROJECT NO. 5243 DWG.NO. 364-5243-D2.1-25 OXFORD RETENTION BASIN AND PUMP STATION ·· DWG.NO.507 D1.1-22 OXFORD RETENTION BASIN AND OUTLET SYSTEM IMPROVEMENT ..DWG.NO.507 D3.1-15 PROJECT NO 3872 MARINA DEL RAY LOW FLOW DIVERSION. DWG.NO. 364-5243-D10.1-11 SURVEY NOTES PWFB 1015-654, 764, 1099 to 1102 PWLB 1015-996 to 1001 ADMIRALTY WAY SETTLEMENT REPAIR

PROJ ID NO. RDC0015061

COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC WORKS

OXFORD RETENTION BASIN MULTI-USE ENHANCEMENT PROJECT



INDEX TO PROJECT PLANS

SH.NO.	DESCRIPTION
	TITLE SHEET
	GENERAL NOTES, STRUCTURAL NOTES, STRUCTURAL DESIGN
- .	CRITERIA, AND INDEX TO STANDARD PLANS
3.	SITE PLAN EXISTING FACILITIES
4.	SITE GRADING PLAN
5.	BASIN PROFILE AND CROSS SECTION DETAILS
	ADMIRALTY AVE WALKING TRAIL PLAN, PROFILE AND DETAILS
7.	RETAINING WALL PLAN, PROFILE AND DETAILS
8. 9.	TIDE GATE ACCESS RAMP PLAN, PROFILE AND DETAILS BASIN BERM PLAN, PROFILE AND DETAILS
9. 10.	BOAT RAMP PLAN AND DETAILS AT PROJECT NO. 3872
	OXFORD AVE CATCH BASIN MODIFICATION AND DETAILS
12.	STRUCTURAL CATWALK DETAIL FOR TIDE GATE CONTROL HOUSE
13.	TRASH EXCLUDER
	MECHANICAL PLANS
ME-1	MECHANICAL SITE PLAN AND TIDE GATE OPERATION SEQUENCE
ME-2	MECHANICAL EQUIPMENT LAYOUT
ME-3	
ME-5	ELECTRICAL DEMOLITION AND SITE ELECTRICAL SINGLE LINES AND WIRING DIAGRAMS
IVIL-5	ELECTRICAL SINGLE LINES AND WINING DIAGRAMS
	LANDSCAPE PLANS
	LANDSCAPE PLAN KEY MAP
LS-1.2	NOTES, ABBREVIATIONS, CONSTRUCTION &
1004	MATERIALS LEGEND
LS-2.1 LS-2.2	CONSTRUCTION PLAN CONSTRUCTION PLAN
LS-2.2 LS-2.3	CONSTRUCTION PLAN
LS-2.4	CONSTRUCTION PLAN
LS-2.5	ENLARGEMENTS
LS-2.6	SECTIONS
	CONSTRUCTION DETAILS
	CONSTRUCTION DETAILS
LS-2.9	CONSTRUCTION DETAILS CONSTRUCTION DETAILS
	CONSTRUCTION DETAILS CONSTRUCTION DETAILS
LS-3.0	IRRIGATION LEGENDS
LS-3.1	HYDROZONE PLAN
	IRRIGATION PLAN
	IRRIGATION PLAN
LS-3.4 LS-3.5	IRRIGATION PLAN IRRIGATION PLAN
	IRRIGATION PLAN IRRIGATION DETAILS
	IRRIGATION DETAILS
LS-4.0	PLANTING LEGEND AND NOTES
LS-4.1	PLANTING PLAN
	PLANTING PLAN
	PLANTING PLAN
	PLANTING PLAN PLANTING DETAILS
LO 4.0	TE WITH BETT WES
	ELECTRICAL PLANS
E-0.1	ELECTRICAL LEGEND, GENERAL NOTES, DETAILS, ONE-LINE DIAGRAM
E-0.2	SPECIFICATIONS
E-0.3	DETAILS ELECTRICAL SITE PLAN
E-1.0 E-2.0	ELECTRICAL SITE PLAN ELECTRICAL SITE PLAN
E-3.0	ELECTRICAL SITE PLAN
E-4.0	ELECTRICAL SITE PLAN
- - :	TRAFFIC PLAN
TP-1	SIGNING AND STRIPPING PLAN

APPROVED GAIL FARBER DIRECTOR OF PUBLIC WORKS TWO DAYS BEFORE YOU DIG CALL **USA** TOLL FREE BY ______ASSISTANT DEPUTY DIRECTOR 1-800-227-2600 SUBMITTED DATE MK DESCRIPTION REVISIONS

CHARLES C. CHEN C63209

COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC WORKS

OXFORD RETENTION BASIN MULTI-USE ENHANCEMENT PROJECT

TITLE SHEET DWG 507-D4.1 PROJECT ENGINEER DATE FCC0001176 JOB JX0039 SHEET 1 OF 13

DATE. \$DATE\$ TIME. \$TIME\$ FILE. \$FILEL\$

PROJECT

GENERAL NOTES

OTHERWISE SHOWN.

- 1. ELEVATIONS SHOWN ARE IN FEET ABOVE MEAN SEA LEVEL BASED ON L.A. CITY 1980 ADJUSTMENT, NGVD 1929 DATUM
- 2. CENTERLINE STATIONS ARE AS SHOWN ON PLANS.
- 3. STATIONS AND INVERT ELEVATIONS OF PIPE INLETS SHOWN ON THE PROFILES ARE AT THE INSIDE FACE OF THE CONDUIT, UNLESS
- 4. BENCHING OF THE EMBANKMENTS SHALL BE AS SPECIFIED IN SECTION 300-4.4 OF THE GREEN BOOK.
- 5. ALL EXISTING UTILITIES SHOWN ON THE PLANS ARE THE PROPERTY OF THE OWNERS LISTED ON SHEET 1, UNLESS OTHERWISE NOTED.
- 6. EXISTING UTILITIES SHALL BE MAINTAINED IN PLACE BY THE CONTRACTOR, UNLESS OTHERWISE NOTED, AND ALL UTILITIES CROSSING THE TRENCH SHALL BE TEMPORARILY SUPPORTED TO THE SATISFACTION OF THE OWNER.
- 7. THE CONTRACTOR SHALL MAKE EXPLORATORY EXCAVATIONS TO DETERMINE THE DEPTH AND LOCATION OF EXISTING UTILITIES WHERE SO INDICATED BY THE SYMBOL "/\".
- 8. ALL RESURFACING, CURBS, GUTTERS, SIDEWALKS, DRIVEWAYS AND OTHER EXISTING IMPROVEMENTS TO BE RECONSTRUCTED SHALL BE CONSTRUCTED AT THE SAME ELEVATION AND LOCATION AS THE EXISTING IMPROVEMENTS, UNLESS OTHERWISE NOTED.
- 9. THE WORK SHOWN ON THESE DRAWINGS REQUIRES THE PRIME CONTRACTOR TO HAVE A VALID CLASS A OR C42 LICENSE ISSUED BY THE STATE OF CALIFORNIA.
- 10. ALL FIELD BOOK REFERENCES ARE TO LOS ANGELES COUNTY DEPARTMENT OF PUBLIC WORKS FIELD BOOKS, UNLESS OTHERWISE NOTED

CONCRETE REMOVAL NOTES

CONCRETE REMOVAL SHALL BE DONE IN THE FOLLOWING SEQUENCE:

- WHERE THE PLAN INDICATE THE EXISTING CONCRETE IS TO BE REMOVED AND THE EXISTING REINFORCEMENT IS REQUIRED TO EXTEND THROUGH THE NEW JOINT, CONCRETE SHALL BE REMOVED IN THE FOLLOWING SEQUENCE:
 - THE CONTRACTOR SHALL MAKE A SUFFICIENT NUMBER OF EXPLORATORY HOLES IN THE EXISTING SLAB TO VERIFY HORIZONTAL SPACING AND CONCRETE COVER OVER EXISTING REINFORCEMENT. THE DEPTH OR EXACT LOCATION OF SAW CUTS MAY VARY AS DETERMINED BY THE ENGINEER IN THE FIELD BASED ON INFORMATION OBTAINED FROM EXPLORATORY HOLES.
 - A SAW CUT SHALL BE MADE ONE AND ONE-HALF INCHES DEEP AT THE REMOVAL LIMITS. CARE SHALL BE EXERCISED IN SAWING AT THE REMOVAL LIMITS SO AS NOT TO CUT THE REINFORCING STEEL IN THE REMAINING SLAB. THE EXISTING REINFORCING STEEL SHALL BE RETAINED AND EXTENDED INTO THE NEW CONSTRUCTION AS INDICATED ON THE PLANS. ANY STEEL INADVERTENTLY CUT OR DAMAGED SHALL BE REPLACED WITH DOWELING AT CONTRACTORS EXPENSE.
 - USING HAND-HELD EQUIPMENT, CAREFULLY REMOVE THE CONCRETE FOR THE FULL DEPTH OF THE SLAB AND FOR A MINIMUM DISTANCE FROM THE SAW CUT EQUAL TO THE LONGEST EXTENSION OF THE EXISTING BARS TO BE EXTENDED INTO THE NEW CONSTRUCTION. THIS EXTENSION SHALL BE 30 BAR DIAMETERS, UNLESS OTHERWISE NOTED.
 - EXISTING REINFORCEMENT SHALL BE CUT TO THE REQUIRED BAR EXTENSIONS.
 - THE REMAINING CONCRETE MAY BE REMOVED BY ANY SUITABLE METHOD UPON APPROVAL OF THE ENGINEER, WHO SHALL BE THE SOLE JUDGE OF THE USE OF ANY CONCRETE REMOVAL EQUIPMENT, EXPLOSIVE WRECKING BALL, OR OTHER SIMILAR DEVICES. METHODS AND EQUIPMENT WHICH ARE LIKELY TO DAMAGE THE CONCRETE TO BE LEFT IN PLACE SHALL NOT BE USED.

STRUCTURAL NOTES

- 1. DIMENSIONS FROM FACE OF CONCRETE TO STEEL ARE TO CENTER OF BAR, UNLESS OTHERWISE SHOWN. CONCRETE DIMENSIONS SHALL BE MEASURED HORIZONTALLY OR VERTICALLY ON THE PROFILE, AND PARALLEL TO OR AT RIGHT ANGELS (OR RADIALLY) TO CENTER LINE OF CONDUIT ON THE PLAN EXCEPT AS OTHERWISE SHOWN. 3. ALL BAR BENDS AND HOOKS SHALL CONFORM TO THE AMERICAN CONCRETE INSTITUTE'S "BUILDING CODE REQUIREMENTS FOR REINFORCED CONCRETE". LATEST EDITION, SECTION 7.2. 4. PLACING OF REINFORCEMENT SHALL CONFORM TO THE AMERICAN CONCRETE INSTITUTE'S "BUILDING CODE REQUIREMENTS FOR REINFORCED CONCRETE". LATEST EDITION, SECTION 7.3
- 5. TRANSVERSE CONSTRUCTION JOINTS SHALL NOT BE PLACED WITHIN 30 INCHES OF MANHOLE OR JUNCTION STRUCTURE OPENINGS.
- 6. TRANSVERSE CONSTRUCTION JOINTS IN WALLS AND SLABS SHALL BE IN THE SAME PLANE. NO STAGGERING OF JOINTS WILL BE PERMITTED. TRANSVERSE CONSTRUCTION JOINTS SHALL BE NORMAL OR RADIAL TO THE CENTER LINE OF CONSTRUCTION.
- 7. THE TRANSVERSE REINFORCING BARS SHALL TERMINATE ONE AND ONE-HALF INCHES FROM THE CONCRETE SURFACES UNLESS OTHERWISE SHOWN ON THE STRUCTURAL DETAILS.
- 8. EXPOSED SURFACES OF CONCRETE MEMBERS SHALL BE ROUNDED OR BEVELED. NO SPLICES IN TRANSVERSE BARS REINFORCEMENT WILL BE PERMITTED OTHER THAN SHOWN ON THE STRUCTURAL DETAILS WITHOUT APPROVAL OF THE ENGINEER. NO MORE THAN TWO SPLICES WILL BE PERMITTED IN ANY LONGITUDINAL BAR BETWEEN TRANSVERSE JOINTS. SPLICES SHALL BE STAGGERED.
- 10. LONGITUDINAL BARS SHALL BE LAPPED 20 BAR DIAMETERS AT SPLICES. TRANSVERSE BARS SHALL BE LAPPED 30 BAR DIAMETERS AT SPLICES.
- 11. LONGITUDINAL STEEL SHALL TERMINATE TWO INCHES FROM TRANSVERSE CONSTRUCTION JOINTS.
- 12. TRANSVERSE JOINTS SHALL BE SPACED NOT TO EXCEED 50 FEET NOR BE LESS THAN 10 FEET, MEASURED ALONG THE CENTERLINE OF CONSTRUCTION, EXCEPT AS OTHERWISE SHOWN ON THE PLANS.
- 13. AT THE BEGINNING AND ENDING OF ALL POURS, A COMPLETE CURTAIN OF MAIN REINFORCEMENTS SHALL SHALL BE PLACED THREE INCHES FROM THE TRANSVERSE CONSTRUCTION JOINTS.
- 14. ALL REBAR USED IN CONSTRUCTION SHALL BE EPOXEY COATED IN CONFORMANCE WITH ASTM SPECIFICATION A775M AND FIELD INSTALLED IN CONFORMANCE WITH ASTM SPECIFICATION D3963/D3963M

STRUCTURAL DESIGN CRITERIA

L.A.C.F.C.D. STRUCTURAL DESIGN MANUAL DATED APRIL 1982

LIVE LOAD

HS 20-44 unless otherwise noted.

DEAD LOAD

Earth load per Marston's formula: w= 130 pcf Ku=Ku' =0.150 Bd=Outside width of box plus 3 feet Side earth: Rubber dam EFP = 60 pcf Internal water pressure: 62.4 psf per foot of depth Weight of concrete: 150 pcf

ALLOWABLE STRESSES

f'c=4000 psi at 28 days fc =1800 psi fs = 24,000 psin =8 Shear and bond stresses per A.C.I. 318-63

INDEX TO STANDARD PLANS

<u>LACDPW</u> <u>TITLE</u>

STD. PLAN 3090-1 CRITERIA FOR THE DESIGN OF SHORING FOR EXCAVATIONS 3091-1 SAMPLE SHEET FOR USE AS A GUIDE IN PREPARING CALCULATIONS FOR SHORING OF EXCAVATIONS 3093-1 UNIFIED SOIL CLASSIFICATION SYSTEM 6002-1 PORTABLE SECURITY FENCE FOR OPEN TRENCHES 6008-1 MINIMUM PUBLIC SAFETY REQUIREMENT FOR OPEN EXCAVATIONS

SPPWC - 2009 EDITION

STD. PLAN

617-3

120-1 **CURB AND GUTTER BARRIER** 303-3 CURBSIDE GRATING CATCH BASIN 314-3 MODIFICATIONS FOR SIDE OPENING CATCH BASIN 335-2 PIPE CONNECTIONS TO EXISTING STORM DRAINS 381-2 ABANDONMENT SEALS FOR MANHOLES AND INLETS CHAIN LINK FENCE AND GATES 606-3 METAL HAND RAILING 610-3 REINFORCED CONCRETE RETAINING WALL TYPE 1 REINFORCED CONCRETE RETAINING WALL TYPE 7

RETAINING WALL DETAILS


CHARLES C. CHEN C63209 DATE MK DESCRIPTION REVISIONS


COUNTY OF LOS ANGELES DEPARTMENT OF PUBLIC WORKS


OXFORD RETENTION BASIN MULTI-USE ENHANCEMENT PROJECT


GENERAL NOTES, STRUCTURAL NOTES, STRUCTURAL DESIGN CRITERIA AND INDEX TO STANDARD PLANS


PROJECT ENGINEER DATE FCC0001176 JOB JX0039 DWG 507-D4.2






































Oxford Retention Basin Tide Gate ME.dgn 12/26/2012 9:43:27 AM



Oxford Retention Basin Tide Gate ME.dgn 12/26/2012 9:43:40 AM



Oxford Retention Basin Tide Gate ME.dgn 12/20/2012 8:40:29 AM



Oxford Retention Basin Tide Gate ME.dgn 12/20/2012 8:27:06 AM